

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0066	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0013	1st	COM SPC	Emergency Exit by Ceramics Room No. 518 (Building B)	Emergency exit signage is mounted on the ceiling.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character. (2010 ADA Fig.
ACS	0001	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0001	1st	COM SPC	Main Entrance (Building B)	Accessible entrance does not have signage displaying the international symbol of accessibility.	§216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.
ACS	0002	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0002	1st	COM SPC	Women's Accessible Restroom by Main Entrance (Building B)	Door has a non-compliant opening force of 7 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0015	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom (Building B)	Door has a non-compliant opening force of 15 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0024	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0003	1st	COM SPC	Multipurpose Hall (Building B)	Permanent room identifying signage is mounted at 64.75" (1645 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0034	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Stage at Multipurpose Hall (Building B)	Furniture encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).
ACS	0044	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0007	1st	COM SPC	Library Room No. 509 (Building B)	Vision lights are mounted at 52" (1321 mm) above the finished floor.	§404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0047	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0008	1st	COM SPC	Game Room No. 510 (Building B)	Vision lights are mounted at 52" (1321 mm) above the finished floor.	§404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0050	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Game Room No. 510 (Building B)	Computers do not appear to have accessible software.	§508	Title II of the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic and information technology. Per Section 508 ensure computer provides accessible hardware/software.
ACS	0051	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0009	1st	COM SPC	Computer Lab Room B No. 521 (Building B)	Computers do not appear to have accessible software.	§508	Title II of the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic and information technology. Per Section 508 ensure computer provides accessible hardware/software.
ACS	0053	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0010	1st	COM SPC	Craft Room No. 513 (Building B)	Vision lights are mounted at 52.75" (1340 mm) above the finished floor.	§404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0060	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0011	1st	COM SPC	Heavy Art Room No. 517 (Building B)	Permanent room identifying signage is mounted on the hinge side of the door.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0061	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0012	1st	COM SPC	Ceramics Room No. 518 (Building B)	Vision lights are mounted at 52" (1321 mm) above the finished floor.	\$404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0067	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0014	1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Door has a non-compliant opening force of 7 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0089	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0015	1st	COM SPC	Door From Men's Accessible Locker Leading to Pool	Door has a non-compliant opening force of 12 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0090	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Door From Men's Accessible Locker Leading to Pool	Maneuvering clearance on the pull side of the door is 53.75" (1365 mm) wide for a parallel latch approach.	\$404.2.4	Install an automatic door opener or rework door side partition to provide the required 24" (609 mm) min. maneuvering clearance on the pull side of the door for a parallel latch side approach and 54" (1370 mm) min. deep clear floor area (For door with a closer) (2010 ADA Fig. 404.2.4.1). For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerances.
ACS	0091	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0016	1st	COM SPC	Fitness Room No. 522 (Building B)	Vision lights are mounted at 52.25" (1327 mm) above the finished floor.	\$404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0100	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0018	1st	COM SPC	Main Entrance to Neighborhood Center (Building C)	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.
ACS	0104	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0021	1st	COM SPC	Sit and Chat Cafe (Building C)	Permanent room identifying signage is mounted on the door header	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0110	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Server Room No. 0128 (Building C)	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0113	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0023	1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Maneuvering clearance on the pull side of the door is 17.75" (451 mm).	\$404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1). This dimension should be considered acceptable per 1990
ACS	0114	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Door has a non-compliant opening force.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf. This door remains open during business hours
ACS	0127	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom By Cafeteria (Building C)	Door has a non-compliant opening force of 15 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0134	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0025	1st	COM SPC	Emergency Exit By Electrical Data Room No. 124 (Building B)	Permanent room identifying signage is mounted over the door header.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0143	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0028	1st	COM SPC	Auto Tag Office (Building B)	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0145	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0029	1st	COM SPC	Door From Auto Tag Office Leading to Building B	Maneuvering clearance on the pull side of the door is 17.5" (444 mm).	\$404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0146	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Door From Auto Tag Office Leading to Building B	Vision lights are mounted at 51.25" (1302 mm) above the finished floor.	\$404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0147	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Door From Auto Tag Office Leading to Building B	Door has a non-compliant opening force of 15 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0148	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0030	1st	COM SPC	Door Leading to Building A	Maneuvering clearance on the pull side of the door is 17.25" (438 mm).	\$404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0149	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Door Leading to Building A	Door has a non-compliant opening force of 8 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0151	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Ramp Connecting Building A to Building B	Handrail encroaches over maneuvering clearance on the pull side of the door reducing it to 43" (1092 mm).	\$404.2.4	Rework handrails to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0152	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0032	1st	COM SPC	Outdoor Seating Area by Ramp Connecting Building A to Building B	Door has a non-compliant opening force of 10 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0154	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0033	1st	COM SPC	Personal Care Room No. 625	Permanent room identifying signage is mounted at 63.5" (1613 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0175	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0038	1st	COM SPC	Dining Room No. 621	Vision lights are mounted at 52.25" (1327 mm) above the finished floor.	§404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0177	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0039	1st	COM SPC	Day Room 1 No. 609	Door has a non-compliant opening force of 10 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0205	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0043	1st	COM SPC	Fourth Accessible Restroom (From Right to Left) in Day Room 1	Door has a non-compliant opening force of 8 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0215	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0044	1st	COM SPC	Nurse's Station Room No. 607	Vision lights are mounted at 52.25" (1327 mm) above the finished floor.	§404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0221	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0048	1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Lockers encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate lockers to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0222	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Door has a non-compliant opening force of 7 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0250	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0053	1st	COM SPC	Women's Accessible Locker Room No. 526	Door has a non-compliant opening force of 7 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0281	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0054	1st	COM SPC	Door From Women's Accessible Locker Leading to Pool	Door has a non-compliant opening force of 8 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0290	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Pool Area	Emergency exit sign is mounted on the ceiling	§703.4.1	Provide signage on both side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0294	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Recreation Room No. 108 (Building C)	Furniture encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).
ACS	0296	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Recreation Room No. 108 (Building C)	Vision lights are mounted at 52.25" (1327 mm) above the finished floor.	§404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0297	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0057	1st	COM SPC	Recreation Room 2 No. 109 (Building C)	Vision lights are mounted at 52" (1321 mm) above the finished floor.	§404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0298	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0058	1st	COM SPC	Craft Room No. 117 (Building C)	Vision lights are mounted at 52" (1321 mm) above the finished floor.	§404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0299	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0059	1st	COM SPC	Computer Lab Room No. 112 (Building C)	Vision lights are mounted at 52" (1321 mm) above the finished floor.	§404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0300	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Computer Lab Room No. 112 (Building C)	Computers do not appear to have accessible software.	§508	Title II of the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic and information technology. Per Section 508 ensure computer provides accessible hardware/software
ACS	0302	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0060	1st	COM SPC	Ceramics Room No. 115 (Building C)	Display encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate display to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).
ACS	0306	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0061	1st	COM SPC	Lounge Room No. 107 (Building C)	Table encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate table to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0310	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Lounge Room No. 107 (Building C)	Door has a non-compliant opening force of 7 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0311	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0062	1st	COM SPC	Door Leading to Building C	Maneuvering clearance on the pull side of the door is 12" (305 mm).	\$404.2.4	Install an automatic door opener to comply with requirements for an 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0315	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces on NW corner of Facility	Accessible parking space on right has sign obstructed by a branch	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.
ACS	0316	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0064	1st	COM SPC	Accessible Route From Public Rights-of-Way (NW corner of Facility)	There is no signage posted indicating the location of an accessible entrance.	\$216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).
ACS	0318	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route From Public Rights-of-Way (NW corner of Facility)	The surface of the accessible route (sidewalk) is not slip resistant due to man hole cover.	\$403.2	Rework or repave accessible route to provide a surface that is stable, firm and slip resistant, with a cross slope not exceeding 2%.
ACS	0319	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route From Public Rights-of-Way (NW corner of Facility)	Accessible route has a non-compliant vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 (2010 ADA Fig. 303.3).
ACS	0323	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0066	1st	COM SPC	Accessible Route Leading to Main Entrance (NW corner of Facility)	Accessible route has a non-compliant cross slope of 4.3 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0324	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Main Entrance (NW corner of Facility)	Accessible route has a non-compliant cross slope of 3.6 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0325	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0067	1st	COM SPC	Passenger Loading Zone (NW corner of Facility)	Passenger loading zone does not have signage displaying the international symbol of accessibility.	\$503	Provide signage displaying the International symbol of accessibility at passenger loading zone.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0326	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Passenger Loading Zone (NW corner of Facility)	Passenger loading zone has a 4.4 % non-compliant surface slope on the access aisle.	\$503.4	Restripe to provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).
ACS	0327	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0068	1st	COM SPC	Accessible Route Leading to Building B	The sign indicating the location of the accessible route leading to building B does not provide the international symbol of accessibility, and it is not really visible until you are close to the corner.	\$216.6	Post signage with the international symbol of accessibility indicating location of the accessible entrance serving the facility. relocate sign closer to main entrance. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).
ACS	0329	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Building B	Ramp handrails do not have extensions.	\$505.10.1	Provide handrails extensions 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig. 505.10.1).
ACS	0332	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Building B	Ramp handrails do not have extensions.	\$505.10.1	Provide handrails extensions 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig. 505.10.1).
ACS	0333	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Building B	Top landing has a non-compliant surface slope of up to 3.3%	\$405.7.1	Rework landing to provide a surface slope not exceeding 2% in all directions (2010 ADA Fig. 405.7).
ACS	0334	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0069	1st	COM SPC	Passenger Loading Zone by Building B	Passenger loading zone does not have signage displaying the international symbol of accessibility.	\$503	Provide signage displaying the International symbol of accessibility at passenger loading zone.
ACS	0337	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0071	1st	COM SPC	Accessible Route Leading to First Set Accessible Parking Spaces on North Side	The only means of access to the first set of accessible parking spaces on the north of side is by stairs.	\$405.2, \$403.3, \$403.4, \$405.7, \$405.8, \$405.9.1, \$405.9.2	Rework area to provide a switch back ramp with the least running slope possible not to exceed 8.33% (1:12) and cross slopes not exceeding 2% (1:48). Install handrails between 34" and 38" (863 mm - 965 mm) above the finished floor to the top of gripping surfaces, with extensions that project 12" (304 mm) min. beyond the top and bottom of the ramp segment. A minimum clearance of 36" (914 mm) is required between the
ACS	0338	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0072	1st	COM SPC	First Set Accessible Parking Spaces on North Side of Facility	First accessible parking space (from left to right) does not have signage indicating accessible parking.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.
ACS	0340	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Set Accessible Parking Spaces on North Side of Facility	Second accessible parking space (from left to right) has signage indicating accessible parking covered by a branch	\$502.6	Remove branch to allow a clear vision of signage indicating accessible parking.
ACS	0342	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Set Accessible Parking Spaces on North Side of Facility	Second access aisle (from left to right) has a non-compliant surface slope of up to 4.8 % due to a catch basin	\$502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0344	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0073	1st	COM SPC	Accessible Route Leading to Second Set Accessible Parking Spaces on North Side	The only means of access to the second set of accessible parking spaces on the north of side is by stairs.	§405.2, §403.3, §403.4, §405.7, §405.8, §405.9.1	Rework area to provide a switch back ramp with the least running slope possible not to exceed 8.33% (1:12) and cross slopes not exceeding 2% (1:48). Install handrails between 34" and 38" (863 mm - 965 mm) above the finished floor to the top of gripping surfaces, with extensions that project 12" (304 mm) min. beyond the top and bottom of the ramp segment.
ACS	0345	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0074	1st	COM SPC	Second Set of Accessible Parking Spaces on North Side of Facility	First accessible parking space (from left to right) does not have signage indicating accessible parking.	§502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.
ACS	0346	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Set of Accessible Parking Spaces on North Side of Facility	First accessible parking space (from left to right) has a non-compliant surface slope of up to 3.7%	§502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0347	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Set of Accessible Parking Spaces on North Side of Facility	Second accessible parking space (from left to right) has a non-compliant surface slope of up to 2.8%	§502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0348	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Set of Accessible Parking Spaces on North Side of Facility	Third accessible parking space (from left to right) has a non-compliant surface slope of up to 2.6%	§502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0349	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Set of Accessible Parking Spaces on North Side of Facility	Second access aisle (from left to right) has a non-compliant surface slope of up to 2.4 %.	§502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.
ACS	0350	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Set of Accessible Parking Spaces on North Side of Facility	Fourth accessible parking space (from left to right) has a non-compliant surface slope of up to 2.5% due to a catch basin	§502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0351	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0075	1st	COM SPC	Passenger Loading Zone by Building C (Neighborhood Senior Center)	Passenger loading zone does not have signage displaying the international symbol of accessibility.	§503	Provide signage displaying the International symbol of accessibility at passenger loading zone.
ACS	0352	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Passenger Loading Zone by Building C (Neighborhood Senior Center)	Passenger loading zone has a 2.4 % non-compliant surface slope.	§503.4	Restripe to provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).
ACS	0353	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Passenger Loading Zone by Building C (Neighborhood Senior Center)	Passenger loading zone has a 2.8 % non-compliant surface slope at access aisle.	§503.4	Restripe to provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).
ACS	0354	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0076	1st	COM SPC	Two Accessible Parking Spaces On Left Side of Entrance to Building C (Front Side)	First accessible parking (from left to right) has signage indicating accessible parking mounted at 59.5" (1511 mm) above the finished floor.	§502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.
ACS	0355	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Left Side of Entrance to Building C (Front Side)	First accessible parking space (from left to right) has a non-compliant surface slope of up to 3.1%	§504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0357	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Left Side of Entrance to Building C (Front Side)	Second accessible parking (from left to right) has signage indicating accessible parking mounted at 57.5" (1460 mm) above the finished floor.	§502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.
ACS	0359	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0077	1st	COM SPC	Two Accessible Parking Spaces On Left Side of Entrance to Building C (Back Side)	First accessible parking (from left to right) has signage indicating accessible parking mounted at 57.25" (1424 mm) above the finished floor.	§502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0362	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Left Side of Entrance to Building C (Back Side)	Second accessible parking (from left to right) has signage indicating accessible parking mounted at 59.5" (1511 mm) above the finished floor.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.
ACS	0369	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Right Side of Entrance to Building C (Back Side)	Second accessible parking (from left to right) has signage indicating accessible parking mounted at 54.5" (1384 mm) above the finished floor.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.
ACS	*0312	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0063	1st	COM SPC	Two Accessible Parking Spaces on NW corner of Facility	Accessible parking space on left has a 2.5 % non-compliant surface slope.	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0313	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces on NW corner of Facility	Access aisle has a non-compliant surface slope of up to 2.4%	\$502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.
ACS	*0314	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces on NW corner of Facility	Accessible parking space on right has a non-compliant surface slope of up to 3.0%	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0317	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route From Public Rights-of-Way (NW corner of Facility)	Accessible route has a non-compliant cross slope of 2.5 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	*0330	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Building B	First leg of the ramp has slopes of up to 6.3 % runs 30 ft (9.14 mt) and does not have the required handrails on both sides.	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 A)
ACS	*0331	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Building B	Second leg of the ramp has slope of up to 6.3 % runs 30 ft (9.14 mt) and does not have the required handrails on both sides.	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 A)
ACS	*0335	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Passenger Loading Zone by Building B	Passenger loading zone has a 5.2 % non-compliant surface slope at access aisle.	\$503.4	Restripe to provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).
ACS	*0339	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Set Accessible Parking Spaces on North Side of Facility	First accessible parking space (from left to right) has a non-compliant surface slope of up to 3.3%	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0341	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Set Accessible Parking Spaces on North Side of Facility	Third accessible parking space (from left to right) has a non-compliant surface slope of up to 3.3%	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0343	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Set Accessible Parking Spaces on North Side of Facility	Fourth accessible parking space (from left to right) has a non-compliant surface slope of up to 4.1% due to a catch basin.	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	*0356	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Left Side of Entrance to Building C (Front Side)	Access aisle has a 3.4 % non-compliant running slope.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.
ACS	*0358	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Left Side of Entrance to Building C (Front Side)	Second accessible parking space (from left to right) has a non-compliant surface slope of up to 3.4%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0360	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Left Side of Entrance to Building C (Back Side)	First accessible parking space (from left to right) has a non-compliant surface slope of up to 3.1%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0361	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Left Side of Entrance to Building C (Back Side)	Access aisle has a 3.3 % non-compliant running slope.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.
ACS	*0363	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Left Side of Entrance to Building C (Back Side)	Second accessible parking space (from left to right) has a non-compliant surface slope of up to 4.5%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0364	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0078	1st	COM SPC	Two Accessible Parking Spaces On Right Side of Entrance to Building C (Front Side)	First accessible parking space (from left to right) has a non-compliant surface slope of up to 2.6%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0365	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Right Side of Entrance to Building C (Front Side)	Access aisle has a 3.0 % non-compliant running slope.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.
ACS	*0366	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Right Side of Entrance to Building C (Front Side)	Second accessible parking space (from left to right) has a non-compliant surface slope of up to 2.7%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0367	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0079	1st	COM SPC	Two Accessible Parking Spaces On Right Side of Entrance to Building C (Back Side)	First accessible parking space (from left to right) has a non-compliant surface slope of up to 2.7%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0368	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Right Side of Entrance to Building C (Back Side)	Access aisle has a 3.3 % non-compliant running slope.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.
ACS	*0370	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Two Accessible Parking Spaces On Right Side of Entrance to Building C (Back Side)	Second accessible parking space (from left to right) has a non-compliant surface slope of up to 4.5%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0003	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom by Main Entrance (Building B)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.75" (1441 mm) above the finished floor.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0004	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom by Main Entrance (Building B)	Sanitary napkin dispenser requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0007	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom by Main Entrance (Building B)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 57.5" (1460 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).
ACS	0008	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom by Main Entrance (Building B)	Accessible toilet compartment (stall) door is located at 6" (152 mm) from the side wall or partition farthest from the water closet	§604.8.2.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the side wall or partition farthest from the water closet (For door located in front of partition) (2010 ADA Fig. 604.8.1.1)
ACS	0009	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom by Main Entrance (Building B)	Toilet seat cover dispenser is mounted 8.75" (222 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0010	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom by Main Entrance (Building B)	Toilet seat cover dispenser is mounted beyond reach ranges at 52" (1321 mm) above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0011	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom by Main Entrance (Building B)	Accessible toilet compartment (stall) is 59.25" (1505 mm) deep by 59" (1499 mm) wide.	§604.8.1.1	Relocate stall partitions to provide a 60" (1524 mm) min. wide by 56" (1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).
ACS	0012	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Corridor by Women's Accessible Restroom (Building B)	Trash bin encroaches over hand sanitizer clear floor space.	§305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at hand sanitizer (2010 ADA Figs. 305.3-305.5).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0013	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Corridor by Women's Accessible Restroom (Building B)	Hand sanitizer is mounted beyond required reach allowed for approach provided and is mounted at 55" (1397 mm) above the finished floor.	§308.2.1	Lower or install hand sanitizer at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0014	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom (Building B)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0018	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom (Building B)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.25" (1505 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0019	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom (Building B)	Accessible toilet compartment (stall) door is located at 5" (127 mm) from the front partition.	§604.8.1.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the front partition (For door located in sidewall or partition) (2010 ADA Fig. 604.8.1.2)
ACS	0020	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom (Building B)	Toilet seat cover dispenser is mounted 7" (178 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0021	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom (Building B)	Water closet has the rear wall grab bar mounted at 22" (559 mm) perpendicular from the water closet centerline the outer flange (open side) of the grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0022	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom (Building B)	Accessible toilet compartment (stall) is 59.5" (1511 mm) wide by 58.75" 1492 mm) deep.	§604.8.1.1	Relocate stall partitions to provide a 60" (1524 mm) min. wide by 56" 1422 mm) min. deep accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0023	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom (Building B)	Urinal is mounted at 17.5" (444 mm) above the finished floor to top of rim.	\$605.2	Lower urinal and mount at 17" (431 mm) max. above the finished floor to top of rim. (2010 ADA Fig. 605.2). Per 2010 ADA section 213.3 urinals are only required to comply with section 605 where more than one urinal is provided.
ACS	0025	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Multipurpose Hall (Building B)	Clothes rod is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor.	\$308.2.1	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0026	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Multipurpose Hall (Building B)	Shelf is mounted at 61.25" (1556 mm) above the finished floor to the top	\$308.2.1	Lower or install shelf at 48" (1219 mm) max. above the finished floor to highest shelf (2010 ADA Fig. 308.2.1).
ACS	0027	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Multipurpose Hall (Building B)	Trash bin encroaches over hand sanitizer clear floor space.	\$305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0028	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Multipurpose Hall (Building B)	Hand sanitizer is mounted at 56.75" (1441 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install hand sanitizer at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0029	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0004	1st	COM SPC	Accessible Route Leading to Stage at Multipurpose Hall (Building B)	Shopping carts and boxes encroach into passage width reducing it to less than 36" (914 mm).	\$403.5.1	Relocate shopping carts and boxes to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).
ACS	0030	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Stage at Multipurpose Hall (Building B)	Ramp has non-compliant extensions.	\$505.10.1	Provide handrails extensions 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig. 505.10.1).
ACS	0031	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Stage at Multipurpose Hall (Building B)	Ramp with a change in direction has a 57" by 57" (1448 by 1448 mm) wide landing.	\$405.7.4	Rework ramp to provide 60" by 60" (1524 mm by 1524 mm) min. long landing, for ramps with a change of direction and runs rising over 30" (762 mm) (2010 ADA Fig. 405.7).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0032	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Stage at Multipurpose Hall (Building B)	Boxes encroach into landing at change in direction.	\$405.7.4	Remove boxes to provide 60" by 60" (1524 mm by 1524 mm) min. long landing, for ramps with a change of direction and runs rising over 30" (762 mm) (2010 ADA Fig. 405.7).
ACS	0035	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0005	1st	COM SPC	Servery No. 208 (Building B)	Cup dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58.75" (1492 mm) above the	\$308.2.1	Place plastic cup dispensers at 44" (1219 mm) max. above the finished floor, over a 20"-25" (510 mm - 1120 mm) max. obstruction, and at 15" (381 mm) min. above the finished floor. Lower or install beverage dispenser control at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Implement policy to have food service workers assist disabled senior citizens pour their beverages from the dispensers, and post signage indicating that assistance is available upon request. (§36.304 (f) and §36.305 (b) (3))
ACS	0036	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Servery No. 208 (Building B)	Beverage dispenser control is mounted beyond required reach allowed for approach provided and is mounted at 54.75" (1391 mm) above the finished floor.	\$308.2.1	Ice tea dispenser is mounted beyond required reach allowed for approach provided and is mounted at 60.25" (1530 mm) above the finished floor to the highest operable part.
ACS	0037	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Servery No. 208 (Building B)	Ice tea dispenser is mounted beyond required reach allowed for approach provided and is mounted at 60.25" (1530 mm) above the finished floor to the highest operable part.	\$308.2.1	Condiment dispenser is mounted beyond required reach allowed for approach provided and is mounted at 64.75" (1645 mm) above the finished floor.
ACS	0038	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Servery No. 208 (Building B)	Condiment dispenser is mounted beyond required reach allowed for approach provided and is mounted at 64.75" (1645 mm) above the finished floor.	\$308.2.1	Mug dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor.
ACS	0039	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Servery No. 208 (Building B)	Mug dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor.	\$308.2.1	Paper plates are mounted beyond required reach allowed for approach provided and is mounted at 51.75" (1314 mm) above the finished floor.
ACS	0040	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Servery No. 208 (Building B)	Paper plates are mounted beyond required reach allowed for approach provided and is mounted at 51.75" (1314 mm) above the finished floor.	\$308.2.1	Lunch counter (tray slide) is mounted at 34.75" (883 mm) above the finished floor to the top.
ACS	0041	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Servery No. 208 (Building B)	Lunch counter (tray slide) is mounted at 34.75" (883 mm) above the finished floor to the top.	\$902.3	Relocate or recess TV so that it does not project more than 4" (101 mm) from back wall to outer leading edge or install at 80" (2032 mm) above the finished floor to its bottom leading edge (2010 ADA Fig. 307.2).
ACS	0043	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Corridor by Library (Building B)	TV protrudes into walkway, projecting 5" (127 mm) from back wall, and is mounted at 64.5" (1638 mm) above the finished floor to its bottom leading edge.	\$307.2	Hand sanitizer dispenser is mounted at 51.5" (1308 mm) above the finished floor to highest operable part.
ACS	0045	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Library Room No. 509 (Building B)	Hand sanitizer dispenser is mounted at 51.5" (1308 mm) above the finished floor to highest operable part.	\$308.2.1	Book shelves are mounted at 49.25" (1251 mm) above the finished floor to highest shelf.
ACS	0046	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Library Room No. 509 (Building B)	Book shelves are mounted at 49.25" (1251 mm) above the finished floor to highest shelf.	\$308.2.1	TV does not have the closed caption unit turned on.
ACS	0048	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Game Room No. 510 (Building B)	TV does not have the closed caption unit turned on.	\$36.303 (e)	Tables have a non-compliant 26" (660 mm) knee clearance above the finished floor that is 26" (660 mm) wide.
ACS	0049	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Game Room No. 510 (Building B)	Tables have a non-compliant 26" (660 mm) knee clearance above the finished floor that is 26" (660 mm) wide.	\$902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance, that is 30" (762 mm) wide and has a 17" (430 mm) horizontal projection.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0052	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Computer Lab Room B No. 521 (Building B)	Hand sanitizer is mounted beyond required reach allowed for approach provided and is mounted at 48.5" (1232 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install hand sanitizer at 48" (1219 mm) max. above the finished floor for forward approach to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0054	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Craft Room No. 513 (Building B)	Hand sanitizer is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install at hand sanitizer 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0055	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Craft Room No. 513 (Building B)	Telephone is mounted at 57.25" (1454 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0056	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Craft Room No. 513 (Building B)	Trash bin encroaches over thermostat clear floor space.	§305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0057	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Craft Room No. 513 (Building B)	Trash bin encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate trash bin to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).
ACS	0058	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Craft Room No. 513 (Building B)	Shelf is mounted at 67.5" (1714 mm) above the finished floor.	§308.2.1	Lower or install shelf rack at 48" (1219 mm) max. above the finished floor (2010 ADA Fig. 308.2.1).
ACS	0059	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Craft Room No. 513 (Building B)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 59.75" (1518 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0062	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Ceramics Room No. 518 (Building B)	Shelf is mounted at 65.25" (1657 mm) above the finished floor.	§308.2.1	Lower or install shelf at 48" (1219 mm) max. above the finished floor (2010 ADA Fig. 308.2.1).
ACS	0063	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Ceramics Room No. 518 (Building B)	Telephone is mounted at 57.75" (1467 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0064	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Ceramics Room No. 518 (Building B)	Shelf is mounted at 59.5" (1511 mm) above the finished floor.	§308.2.1	Lower or install shelf at 48" (1219 mm) max. above the finished floor (2010 ADA Fig. 308.2.1).
ACS	0065	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Ceramics Room No. 518 (Building B)	Kiln does not provide the required diameter wheelchair turnaround space.	§304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).
ACS	0068	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Locker hardware requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0069	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Low drinking fountain spout outlet (orifice height) is mounted at 38" (965 mm) above the finished floor.	§602.4	Relocate low drinking fountain and mount at 36" (914 mm) max. above the finished floor to the spout outlet
ACS	0070	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Drinking fountain protrudes into walkway, projecting 18" (457 mm) from back wall, and is mounted at 30" (762 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate and mount low drinking fountain at 27" (685 mm) above the finished floor to its bottom leading edge (2010 ADA Fig. 307.2).
ACS	0071	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Dressing room bench is 9.5" (241 mm) wide.	§803.4	Provide a 20" to 24" (508 mm - 609 mm) max. deep bench, that is 42" (1065 mm) long minimum, fixed to a wall, and mounted 17" min. to 19" max. (431 mm-482 mm) above the finished floor to top of bench.
ACS	0072	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter. <i>This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0073	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.25" (1429 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0074	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 51.75" (1314 mm) above the finished floor.	§308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0075	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Accessible toilet compartment (stall) door is located at 4.75" (121 mm) from the side wall or partition farthest from the water closet	§604.8.1.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the side wall or partition farthest from the water closet (For door located in front of partition) (2010 ADA Fig. 604.8.1.1)
ACS	0076	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Toilet seat cover dispenser is mounted beyond behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 13" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig. 308.2.1).</i>

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0077	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Toilet seat cover dispenser is mounted 10" (254 mm) over the rear wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig. 604.7). Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0080	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Water closet has the rear wall grab bar mounted at 21" (533 mm) perpendicular from the water closet centerline the outer flange (open side) of the grab bar.	§604.5.2	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991
ACS	0081	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Water closet side wall grab bar is mounted at 53.5" (1359 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Relocate hand dryer to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5). A side approach has been provided, no remedial work is necessary
ACS	0082	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Trash bin encroaches over hand dryer clear floor space.	§305.3	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.
ACS	0083	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Transfer shower controls are mounted 14" (356 mm) from the centerline to the edge of the shower.	§608.5.1	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0084	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Shower pray hose requires pinching and tight grasping to operate.	§309.4	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall; and mount between 33" and 36" (838 mm- 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.608.3.1).
ACS	0085	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Transfer shower grab bar is mounted at a point of 17" (432 mm) from the control wall	§608.3.1	Provide an L-shaped seat that extends up to 3" (75 mm) max. from the shower compartment entry, that is recessed 2.5" (63 mm) max. from the seat wall and 1.5" (38 mm) max. from the rear edge of the L-portion of the seat (2010 ADA Fig. 610.3.2).
ACS	0086	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	L-shaped seat is recessed 3" (76 mm) from the seat wall.	§610.3.2	Install a transfer shower seat and mount between 17"- 19" max. (431 mm - 482 mm) above the finished floor to top of seat. The seat shall extend from the back wall to a point within 3" (75 mm) of the compartment entry (2010 ADA Fig. 610.3). For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0087	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Transfer shower seat is mounted at 19.25" (489 mm) above the finished floor to top of seat.	§608.4	

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0088	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Transfer shower stall is 36" by 36.25" (914 by 921 mm).	§608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1).
ACS	0092	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fitness Room No. 522 (Building B)	Exercise machines and equipment have a non-compliant clear floor space.	§1004.1	Relocate exercise machines and equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space, positioned for transfer or use by an individual seated in a wheelchair (2010 ADA Fig. 305.3, 305.5).
ACS	0093	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fitness Room No. 522 (Building B)	Exercise machines encroaches passage width reducing it to less than 36" (914 mm).	§403.5.1	Relocate exercise machines to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).
ACS	0094	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fitness Room No. 522 (Building B)	Exercise machines encroach over paper towel dispenser clear floor space.	§305.3	Relocate paper towel dispenser to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0095	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fitness Room No. 522 (Building B)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 61.25" (1556 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0096	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fitness Room No. 522 (Building B)	Exercise equipment and cabinet encroach over telephone clear floor space.	§305.3	Relocate telephone to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0097	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fitness Room No. 522 (Building B)	Telephone is mounted at 63.5" (1613 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0098	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fitness Room No. 522 (Building B)	Hand sanitizer is mounted at 58.5" (1486 mm) above the finished floor to highest operable part.	§308.2.1	Lower or install hand sanitizer at 48" (1219 mm) max. above the finished floor to highest operable part (2010 ADA Fig. 308.2.1).
ACS	0099	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0017	1st	COM SPC	Fitness Office No. 523 (Building B)	Table has a non-compliant knee clearance and non-compliant clear floor space due to base.	§902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.
ACS	0101	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0019	1st	COM SPC	Lobby at Neighborhood Center (Building C)	Brochure rack is mounted at 62.75" (1594 mm) above the finished floor to highest shelf.	§308.2.1	Lower or install brochure rack at 48" (1219 mm) max. above the finished floor to highest shelf (2010 ADA Fig. 308.2.1).
ACS	0102	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0020	1st	COM SPC	Coat Room by Lobby (Building C)	Clothes rod is mounted beyond required reach allowed for approach provided and is mounted at 48.25" (1226 mm) above the finished floor.	§308.2.1	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements
ACS	0103	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Coat Room by Lobby (Building C)	Shelf is mounted at 53" (1346 mm) above the finished floor.	§308.2.1	Lower or install shelf at 48" (1219 mm) max. above the finished floor (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0105	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Sit and Chat Cafe (Building C)	Tables have a non-compliant knee clearance with a 16" (406 mm) horizontal projection.	§902.2	Replace tables to provide 5% (#) accessible seating spaces with the table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b))
ACS	0106	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Sit and Chat Cafe (Building C)	TV does not have the closed caption unit turned on.	§36.303 (e)	Implement a policy to have the closed caption feature on during business hours.
ACS	0107	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Sit and Chat Cafe (Building C)	Table encroaches over telephone clear floor space.	§305.3	Relocate table to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0108	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Sit and Chat Cafe (Building C)	Telephone is mounted at 58" (1473 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0109	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0022	1st	COM SPC	Server Room No. 0128 (Building C)	Coffee dispenser is mounted beyond required reach allowed for approach provided and is mounted at 63" (1600 mm) above the finished floor.	§308.2.1	Lower or install coffee dispenser control at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Implement policy to have food service workers assist disabled senior citizens pour their beverages from the dispensers, and post signage indicating that assistance is available upon request.
ACS	0111	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Server Room No. 0128 (Building C)	Toaster is mounted beyond required reach allowed for approach provided and is mounted at 51.5" (1308 mm) above the finished floor to the outlet.	§308.2.1	Relocate toasters at 48" (1219 mm) max. above the finished floor to the outlet (2010 ADA Fig. 308.2.1).
ACS	0112	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Server Room No. 0128 (Building C)	Coffee brewer is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor.	§308.2.1	Lower or install coffee dispenser control at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Implement policy to have food service workers assist disabled senior citizens pour their beverages from the dispensers, and post signage
ACS	0115	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0116	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Secondary paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 55.75" (1416 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0117	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Sanitary napkin dispenser requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0120	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Accessible toilet compartment (stall) door is located at 6" (152 mm) from the front partition.	§604.8.1.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the front partition (2010 ADA Fig. 604.8.1.2)

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0121	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Toilet seat cover dispenser is mounted 8.25" (210 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified.
ACS	0122	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0123	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Water closet has the rear wall grab bar mounted at 22" (559 mm) perpendicular from the water closet centerline the outer flange (open side) of the grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of the grab bar. (2010 ADA Fig. 604.5.2)
ACS	0124	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Accessible toilet compartment (stall) is 58.5" (1486 mm) deep by 59.5" 1511 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" (1524 mm) min. wide by 56" (1422 mm) min. deep accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).
ACS	0125	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0024	1st	COM SPC	Men's Accessible Restroom By Cafeteria (Building C)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56" (1422 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0126	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom By Cafeteria (Building C)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0130	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom By Cafeteria (Building C)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0131	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom By Cafeteria (Building C)	Toilet seat cover dispenser is mounted 10" (254 mm) over the side wall grab bar and it is being obstructed by the water closet.	§609.3	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar.
ACS	0132	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom By Cafeteria (Building C)	Accessible toilet compartment (stall) is 58.5" (1486) deep by 59.5" (1511 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" (1524 mm) min. wide by 56" 1422 mm) min. deep accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).
ACS	0133	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom By Cafeteria (Building C)	Low urinal is mounted at 18.25" (464 mm) above the finished floor to top of rim.	§605.2	Install low urinal and mount at 17" (431 mm) max. above the finished floor to top of rim. (2010 ADA Fig. 605.2)
ACS	0135	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0026	1st	COM SPC	Unisex Accessible Restroom by Room No. 109 (Building C)	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 62.25" (1581 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0136	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Unisex Accessible Restroom by Room No. 109 (Building C)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.5" (1435 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0137	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Unisex Accessible Restroom by Room No. 109 (Building C)	Lavatory mirror is mounted at 48" (1219 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0138	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Unisex Accessible Restroom by Room No. 109 (Building C)	Water closet side wall grab bar is mounted at 52.5" (1334 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0139	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Unisex Accessible Restroom by Room No. 109 (Building C)	Toilet seat cover dispenser is mounted 7.5" (190 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>
ACS	0140	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Unisex Accessible Restroom by Room No. 109 (Building C)	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0141	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Unisex Accessible Restroom by Room No. 109 (Building C)	Clear floor space is 66" (1676 mm) wide by 78" (mm) wide and restroom may not provide the required diameter wheelchair turnaround space due to fixtures or trash bin mounted on wall	§304.3	Remove trash bin to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).
ACS	0142	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0027	1st	COM SPC	Vending Machines (Building C)	Vending machine control is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor.	§308.2.1	Lower or install vending machine controls at 48" (1219 mm) max. above the finished floor to permit forward approach to object (2010 ADA Fig. 308.3.1). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>
ACS	0150	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0031	1st	COM SPC	Ramp Connecting Building A to Building B	Ramp handrails do not have extensions at intermediate landing due to a doorway.	§505.10.1	Provide handrails extensions 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig. 505.10.1). There are doors at the intermediate landing, no remedial work is necessary.
ACS	0153	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Outdoor Seating Area by Ramp Connecting Building A to Building B	Tables have a non-compliant 26.75" (679 mm) knee clearance and non-compliant clear floor space provided.	§902.2	Replace tables to provide 30" (762 mm) accessible seating spaces with the table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a minimum leg clearance that is 43" (1092 mm) high.
ACS	0155	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Personal Care Room No. 625	Telephone is mounted at 57.25" (1454 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0156	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0034	1st	COM SPC	Restroom in Personal Care Room No. 625	Toilet seat cover dispenser is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)</i>
ACS	0157	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	Water closet has the rear wall grab bar mounted at 22" (559 mm) perpendicular from the water closet centerline the outer flange (open side) of the grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0158	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	Toilet seat cover dispenser is mounted 10.25" (260 mm) over the rear wall grab bar.	§308.2.1	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar.</i>
ACS	0159	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	Glove dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53.5" (1359 mm) above the finished floor.	§308.2.1	Lower or install glove dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0160	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	Lavatory mirror is mounted at 48.25" (1226 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0161	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	Transfer shower controls are mounted at a point of 14.75" (384 mm) from the back wall	§608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.
ACS	0162	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	Transfer shower stall is 35.75" (908 mm) wide by 36.25" (921 mm) deep.	§608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1).
ACS	0163	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	Shower spray hose requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0164	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	L-shaped seat is recessed 3" (76 mm) from the seat wall	§610.3.2	Provide an L-shaped seat that extends up to 3" (75 mm) max. from the shower compartment entry, that is recessed 2.5" (63 mm) max. from the seat wall and 1.5" (38 mm) max. from the rear edge of the L-portion of the seat (2010 ADA Fig. 610.3.2).
ACS	0165	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	Transfer shower grab bar is mounted at a point of 17.25" (438 mm) from the control wall	§608.3.1	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall; and mount between 33" and 36" (838 mm- 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 610.3.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0166	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	Transfer shower seat is mounted at 19.5" (495 mm) above the finished floor to top of seat.	§608.4	Install a transfer shower seat and mount between 17"- 19" max. (431 mm - 482 mm) above the finished floor to top of seat. The seat shall extend from the back wall to a point within 3" (75 mm) of the compartment entry (2010 ADA Fig. 610.3).
ACS	0167	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Restroom in Personal Care Room No. 625	Shelf is mounted beyond required reach allowed for approach provided and is mounted at 61.75" (1568 mm) above the finished floor.	§603.4	Lower or install shelf between 40"- 48" (1016 mm -1219 mm) max. above the finished floor for forward approach to object.
ACS	0168	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0035	1st	COM SPC	Beauty Shop No. 616	Mirror is mounted at 47" (1194 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Provide a full size mirror mounted at 35" (890 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0169	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Beauty Shop No. 616	Telephone is mounted at 57.5" (1460 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0170	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0036	1st	COM SPC	Recreation Program Supervisor Room No. 618	Exercise machines and equipment have a non-compliant clear floor space.	§1004.1	Relocate exercise machines and equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space, positioned for transfer or use by an individual seated in a wheelchair (2010 ADA Fig. 305.3, 305.5).
ACS	0171	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Recreation Program Supervisor Room No. 618	TV does not have the closed caption unit turned on.	§36.303 (e)	Implement a policy to have the closed caption feature on during business hours.
ACS	0172	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Recreation Program Supervisor Room No. 618	Hand sanitizer dispenser is mounted beyond required reach allowed for approach provided and is mounted at 50.25" (1276 mm) above the finished floor.	§308.2.1	Lower or install hand sanitizer dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply.
ACS	0173	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Recreation Program Supervisor Room No. 618	Fitness equipment encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate fitness equipment to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0176	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Quiet Room No. 619	Telephone is mounted at 57.5" (1460 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0178	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Day Room 1 No. 609	Tables have a non-compliant knee clearance and non-compliant clear floor space due to pedestal base.	§902.2	Replace (1) table to provide accessible seating spaces with the table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0179	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0040	1st	COM SPC	First Accessible Restroom (From Right to Left) in Day Room 1	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 57.5" (1460 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0180	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Right to Left) in Day Room 1	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig. 604.7). Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).</i>
ACS	0182	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Right to Left) in Day Room 1	Toilet seat cover dispenser is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).</i>
ACS	0183	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Right to Left) in Day Room 1	Toilet seat cover dispenser is mounted 10" (254 mm) over the rear wall grab bar.	§308.2.1	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).</i>
ACS	0184	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Right to Left) in Day Room 1	Glove dispenser is mounted behind the water closet	§308.2.1	Relocate glove dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).</i>
ACS	0185	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Right to Left) in Day Room 1	Glove dispenser is mounted beyond required reach allowed for approach provided and is mounted at 62.5" (1588 mm) above the finished floor.	§308.2.1	Lower or install glove dispenser at 48" (1219 mm) max. above the finished floor for an unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).</i>
ACS	0186	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Right to Left) in Day Room 1	Trash bin encroaches into the required diameter wheelchair turnaround space in room reducing it to 52" (1320 mm)	§304.3	Relocate trash bin to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).
ACS	0187	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Right to Left) in Day Room 1	Clear floor space is 59.5" (1511 mm) wide (measured from tile to tile) and does not provide the required diameter wheelchair turnaround space.	§304.3	Reconfigure room's fixtures and/or other partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2). <i>For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0188	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0041	1st	COM SPC	Second Accessible Restroom (From Right to Left) in Day Room 1	Trash bin encroaches over lavatory clear floor space.	§305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0189	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Right to Left) in Day Room 1	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 57.75" (1467 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0190	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Right to Left) in Day Room 1	Trash bin encroaches into the required diameter wheelchair turnaround space in room reducing it to 53" (1346 mm)	§304.3	Relocate trash bin to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).
ACS	0191	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Right to Left) in Day Room 1	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter. <i>For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0192	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Right to Left) in Day Room 1	Lavatory mirror is mounted at 48.5" (1232 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0193	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Right to Left) in Day Room 1	Toilet seat cover dispenser is mounted beyond reach ranges at 55.5" (1410 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2
ACS	0194	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Right to Left) in Day Room 1	Lavatory is mounted at 34.25" (870 mm) from water closet side wall to the outer leading edge.	\$4.19.2 \$604.3.1	conduct barrier removal to the maximum extent feasible. Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA
ACS	0195	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Right to Left) in Day Room 1	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	
ACS	0196	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Right to Left) in Day Room 1	Glove dispenser is mounted beyond reach ranges at 66.5" (1689 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet glove dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0198	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0042	1st	COM SPC	Third Accessible Restroom (From Right to Left) in Day Room 1	Toilet seat cover dispenser is mounted beyond reach ranges at 55.75" (1416 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig. 609.3).
ACS	0199	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Right to Left) in Day Room 1	Glove dispenser is mounted beyond reach ranges at 66.5" (1689 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate glove dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0200	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Right to Left) in Day Room 1	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0201	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Right to Left) in Day Room 1	Lavatory is mounted at 36" (914 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0203	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Right to Left) in Day Room 1	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58.75" (1492 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0204	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Right to Left) in Day Room 1	Trash bin encroaches into the required diameter wheelchair turnaround space in room reducing it to 52.55" (1334 mm)	\$304.3	Relocate trash bin to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).
ACS	0206	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fourth Accessible Restroom (From Right to Left) in Day Room 1	Trash bin encroaches over lavatory clear floor space.	\$305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at lavatory (2010 ADA Figs. 305.3-305.5).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0207	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fourth Accessible Restroom (From Right to Left) in Day Room 1	Trash bin encroaches into the required diameter wheelchair turnaround space in room reducing it to 53" (1346 mm)	§304.3	Relocate trash bin to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).
ACS	0208	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fourth Accessible Restroom (From Right to Left) in Day Room 1	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0209	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fourth Accessible Restroom (From Right to Left) in Day Room 1	Lavatory mirror is mounted at 48.5" (1232 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0210	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fourth Accessible Restroom (From Right to Left) in Day Room 1	Lavatory is mounted at 32" (813 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	§4.19.2 §604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2 conduct barrier removal to the maximum extent feasible within the existing footprint and relocate lavatory at 36" (914 mm) min. from water closet side wall to outer leading edge of lavatory (2010 ADA Fig. 28).
ACS	0211	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fourth Accessible Restroom (From Right to Left) in Day Room 1	Water closet has a 24" (610 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0212	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fourth Accessible Restroom (From Right to Left) in Day Room 1	Toilet seat cover dispenser is mounted beyond reach ranges at 56.5" (1435 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0213	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fourth Accessible Restroom (From Right to Left) in Day Room 1	Glove dispenser is mounted beyond reach ranges at 66.5" (1689 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate glove dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0216	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0045	1st	COM SPC	Adult Day Area	TV does not have the closed caption unit turned on.	§36.303 (e)	Implement a policy to have the closed caption feature on during business hours.
ACS	0217	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Adult Day Area	Lower clothes rod is mounted beyond required reach allowed for approach provided and is mounted at 49.75" (1264 mm) above the finished floor.	§308.2.1	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991
ACS	0218	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Adult Day Area	Shelf is mounted at 53" (1346 mm) above the finished floor to highest shelf.	§308.2.1	Lower or install brochure rack at 48" (1219 mm) max. above the finished floor to highest shelf (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0219	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0046	1st	COM SPC	Outdoor Seating Area by Adult Day Area	Tables at this area have a non-compliant 26.75" (679 mm) knee clearance and non-compliant clear floor space provided.	§902.2	Replace tables to provide 5% accessible seating spaces with the table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b))
ACS	0220	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0047	1st	COM SPC	Lockers by Accessible Restrooms in Day Room 2	Locker hardware will require pinching and tight grasping to operate once the lock has been installed.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0223	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 57.5" (1460 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0224	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Trash bin encroaches over lavatory clear floor space.	§305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at lavatory (2010 ADA Figs. 305.3-305.5).
ACS	0225	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Trash bin encroaches into the required diameter wheelchair turnaround space in room reducing it to 51.75" (1314 mm)	§304.3	Relocate trash bin to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).
ACS	0226	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Lavatory mirror is mounted at 48.75" (1238 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0227	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar. Mount between 33" and 36" (838 mm - 914 mm) above the finished floor.
ACS	0228	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Lavatory is mounted at 35.5" (902 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	§4.19.2 §604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2 relocate lavatory at 36" (914 mm) min. from water closet side wall to outer leading edge of lavatory (2010 ADA Fig. 28).
ACS	0229	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Toilet seat cover dispenser is mounted beyond reach ranges at 52.5" (1334 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0230	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Glove dispenser is mounted beyond reach ranges at 62.5" (1588 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate glove dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted
ACS	0232	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0049	1st	COM SPC	Second Accessible Restroom (From Left to Right) in Day Room 2	Trash bin encroaches into the required diameter wheelchair turnaround space in room reducing it to 53" (1346 mm)	§304.3	Relocate trash bin to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).
ACS	0233	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Left to Right) in Day Room 2	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 57.5" (1460 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0234	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Left to Right) in Day Room 2	Trash bin encroaches over lavatory clear floor space.	\$305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at lavatory (2010 ADA Figs. 305.3-305.5).
ACS	0235	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Left to Right) in Day Room 2	Toilet seat cover dispenser is mounted beyond reach ranges at 52" (1321 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)</i>
ACS	0236	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Left to Right) in Day Room 2	Glove dispenser is mounted beyond reach ranges at 62.25" (1581 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate glove dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0237	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Left to Right) in Day Room 2	Lavatory mirror is mounted at 49" (1245 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0238	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Left to Right) in Day Room 2	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0239	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Left to Right) in Day Room 2	Lavatory is mounted at 34.25" (870 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$4.19.2 \$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). <i>Element does not comply with 1991 standards section 4.19.2 relocate lavatory at 36" (914 mm) min. from water closet side wall to outer leading edge of lavatory (2010 ADA Fig. 28).</i>
ACS	0240	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0050	1st	COM SPC	Third Accessible Restroom (From Left to Right) in Day Room 2	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0241	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Left to Right) in Day Room 2	Trash bin encroaches into the required diameter wheelchair turnaround space in room reducing it to 52.55" (1334 mm)	\$304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0242	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Left to Right) in Day Room 2	Lavatory mirror is mounted at 48.25" (1226 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0243	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Left to Right) in Day Room 2	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0244	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Left to Right) in Day Room 2	Toilet seat cover dispenser is mounted beyond reach ranges at 51.75" (1314 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser to provide a unobstructed approach to dispenser and mount between 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab</i>
ACS	0245	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Left to Right) in Day Room 2	Glove dispenser is mounted beyond reach ranges at 62.25" (1581 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate glove dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0246	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Left to Right) in Day Room 2	Toilet tissue dispenser is mounted 8.5" (216 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser we recommend mounting 1.5" (38 mm) below the grab bar (2010 ADA Fig 604.7 and 609.3)
ACS	0247	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Left to Right) in Day Room 2	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0249	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0052	1st	COM SPC	Reception Area at Building A	Brochure rack is mounted at 51.75" (1314 mm) above the finished floor to highest shelf.	§308.2.1	Lower or install brochure rack at 48" (1219 mm) max. above the finished floor to highest shelf (2010 ADA Fig. 308.2.1).
ACS	0251	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Hand dryer protrudes into walkway, projecting more than 4" (102 mm) from back wall.	§307.2r	Relocate or recess hand dryer so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).
ACS	0252	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.
ACS	0255	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Coat hook is mounted at a non-compliant height above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0256	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). <i>This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0257	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Water closet has the rear wall grab bar mounted at 23" (584 mm) perpendicular from the water closet centerline the outer flange (open side) of the grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0258	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Toilet seat cover dispenser is mounted at 52" (1321 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>
ACS	0259	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Toilet seat cover dispenser is mounted 10.25" (260 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified.</i>
ACS	0262	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Stall doorway opening has a clear width of 30" (762 mm).	\$404.2.3	Rework stall doorway (partitions) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).
ACS	0263	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Toilet seat cover dispenser is mounted beyond reach ranges at 52.5" (1334 mm) above the finished floor.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified.</i>
ACS	0264	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Toilet seat cover dispenser is mounted 9.25" (235 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified.</i>
ACS	0265	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 53.25" (1353 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).
ACS	0266	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Water closet is centered at 21.5" (546 mm) from side wall (Ambulatory Stall).	\$604.2	Relocate water closet and center between 17" and 19" (431 mm - 482 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0267	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Ambulatory accessible compartment (Stall) is 43" (1092 mm) wide by 59.5" (1511 mm) Deep	\$604.8.2.1	Reconfigure ambulatory accessible compartment (stall) to provide a 60"(1524 mm) min. depth and a minimum width of 35" and 37" (890 mm - 940 mm) max. (2010 ADA Fig. 604.8.2).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0268	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Sanitary napkin dispenser controls require pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0269	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 55.75" (1416 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0270	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Secondary paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53.5" (1359 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0271	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Drinking fountain protrudes into walkway, projecting 18.5" (470 mm) from back wall, and is mounted at 28" (711 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate and mount low drinking fountain at 27" (685 mm) above the finished floor to its bottom leading edge (2010 ADA Fig. 307.2).
ACS	0272	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Locker hardware requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0273	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Dressing room bench is 9.5" (241 mm) wide and it is not fixed to a wall.	§803.4	Provide a 20" to 24" (508 mm - 609 mm) max. deep bench, that is 42" (1065 mm) long minimum, fixed to a wall, and mounted 17" min. to 19" max. (431 mm-482 mm) above the finished floor to top of bench.
ACS	0274	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 62" (1575 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0275	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Transfer shower controls are mounted 14.5" (368 mm) from the back wall to the centerline.	§608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0276	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Shower spray hose is mounted at 53.75" (1366 mm) above the finished floor to the centerline.	§607.6	Lower or install shower spray hose at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0277	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Transfer shower grab bar is mounted at a point of 17.5" (444 mm) from the control wall	§608.3.1	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall; and mount between 33" and 36" (838 mm- 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.608.3.1).
ACS	0278	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	L-shaped seat is recessed 3" (76 mm) from the from the seat wall.	§610.3.2	Provide an L-shaped seat that extends up to 3" (75 mm) max. from the shower compartment entry, that is recessed 2.5" (63 mm) max. from the seat wall and 1.5" (38 mm) max. from the rear edge of the L-portion of the seat (2010 ADA Fig. 610.3.2).
ACS	0279	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Transfer shower stall is 36.75"(933 mm) wide.	§608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1).
ACS	0280	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.25" (1480 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).
ACS	0282	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0055	1st	COM SPC	Pool Area	Telephone is mounted at 52" (1321 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0283	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Pool Area	Roll-in shower has non-compliant grab bar configuration.	§608.3	At roll-in shower, replace grab bar configuration, install grab bars on back and side walls, and mount between 33" and 36" (838 mm-914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 608.3.2).
ACS	0284	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Pool Area	Roll-in shower controls are mounted at 50.5" (1283 mm) above the finished floor to the centerline	§608.5.2	Relocate and mount shower controls above the grab bar at 48" (1220 mm) max. above the finished floor to the centerline of the highest operable part (For a standard roll-in shower with out a
ACS	0285	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Pool Area	Shower head is a fixed-type unit.	§608.6	Replace or install additional shower spray unit with a hose that is 59" (1500 mm) min. in length and serves both as a fixed and hand-held unit.
ACS	0286	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Pool Area	Drinking fountain spout outlet (orifice height) is mounted at 36.5" (927 mm) above the finished floor.	§602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet.
ACS	0287	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Pool Area	The pool lift is mounted in an area where the water level exceeds a depth of 48" (1220 mm).	§1009.2.1	Relocate the pool lift and mount in the area of the pool where the water level does not exceed 48" (1220 mm). <i>The minimum depth at this pool is 52" (1320mm) , no remedial work is necessary</i>
ACS	0288	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Pool Area	Pool lift mechanism is not capable of unassisted operation from the deck and water levels (no remote control)	§1009.2.7	Provide a pool lift that is capable of unassisted operation from the deck and water levels.
ACS	0289	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Pool Area	Pool lift is mounted at 10" (254 mm) from the edge of the pool.	§1009.2.2	Provide a pool lift that when in raised position the centerline of the seat is located over the deck and 16" (405 mm) min. from the edge of the pool (2010 ADA Fig. 1009.2.2).
ACS	0291	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Pool Area	The transfer space at the bottom of the platform has a non-compliant 5.2 % surface slope	§1009.5.2	Rework area at the base of the transfer platform to provide a 60" by 60" (1524 mm by 1524 mm) min. clear transfer space, with a surface slope not steeper than 2%, centered along a 24" (610 mm) min. side of the transfer platform (2010 ADA Fig. 1009.5.2). <i>This is a secondary means of entry to the pool, no remedial work is necessary</i>

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0292	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Pool Area	Pool handrails have a 34.5" (876 mm) clear width.	§1009.6.2	Rework handrails to provide a clear width between 20" and 24" (510 mm - 610 mm) max. <i>This is a secondary means of entry to the pool, no remedial work is necessary</i>
ACS	0293	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0056	1st	COM SPC	Recreation Room No. 108 (Building C)	Tables have a non-compliant 29.25" (743 mm) wide knee clearance.	§902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor, that is 30" (762 mm) min. wide and has a 17" (430 mm) horizontal projection.
ACS	0295	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Recreation Room No. 108 (Building C)	Telephone is mounted at 57.75" (1467 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0301	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Computer Lab Room No. 112 (Building C)	Shelf is mounted at 56" (1422 mm) above the finished floor to the top.	§308.2.1	Lower or install shelf at 48" (1219 mm) max. above the finished floor to the top (2010 ADA Fig. 308.2.1).
ACS	0303	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Ceramics Room No. 115 (Building C)	Wall cabinets over the work surface are mounted at 54.25" (1378 mm) above the finished floor to the bottom shelf.	§804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.
ACS	0304	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Ceramics Room No. 115 (Building C)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 60" (1524 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0305	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Ceramics Room No. 115 (Building C)	Shelf is mounted at 64.25" (1632 mm) above the finished floor.	§308.2.1	Lower or install brochure rack at 48" (1219 mm) max. above the finished floor (2010 ADA Fig. 308.2.1).
ACS	0307	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Lounge Room No. 107 (Building C)	Wall cabinets over the work surface are mounted at 58.5" (1486 mm) above the finished floor to the bottom shelf.	§804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.
ACS	0308	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Lounge Room No. 107 (Building C)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58.75" (1492 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).
ACS	0309	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Lounge Room No. 107 (Building C)	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53.75" (1365 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0320	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0065	1st	COM SPC	Accessible Route Leading to Bocce Courts (NW corner of Facility)	Accessible route has a non-compliant vertical change in level at transition from sidewalk.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a curb ramp or ramp (2010 ADA Fig. 303.3).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0321	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Bocce Courts (NW corner of Facility)	The surface of the accessible route is unstable and has loose material.	§302.1	Rework and clean sidewalk to provide a stable, firm, and slip-resistant floor surface.
ACS	0322	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Bocce Courts (NW corner of Facility)	Accessible route has a non-compliant vertical change in level at transition to outdoor seating area in front of bocce courts	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of ramp (2010 ADA Fig. 303.3).
ACS	0336	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0070	1st	COM SPC	Outdoor Seating Area on North Side of Building	Tables have a non-compliant knee clearance with a 17" (430 mm) horizontal projection and non-compliant clear floor space due to base.	§902.2	Provide accessible seating spaces with table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b))
ACS	*0033	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Stage at Multipurpose Hall (Building B)	Top segment of ramp has a non-compliant surface slope of up to 10.7 %.	§405.2	Rework ramp to provide a running slope not exceeding 8.33%.
ACS	0005	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom by Main Entrance (Building B)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0006	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom by Main Entrance (Building B)	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0016	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom (Building B)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0017	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom (Building B)	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0078	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0079	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Locker Room No. 525(Building B)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0118	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0119	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Restroom By Cafeteria (Building C)	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0128	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom By Cafeteria (Building C)	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0129	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Men's Accessible Restroom By Cafeteria (Building C)	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0181	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Right to Left) in Day Room 1	Toilet tissue dispenser is mounted 5" (127 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser we recommend mounting 1.5" (38 mm) below the grab bar (2010 ADA Fig 604.7 and 609.3)
ACS	0197	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Second Accessible Restroom (From Right to Left) in Day Room 1	Toilet tissue dispenser is mounted 6" (152 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser we recommend mounting 1.5" (38 mm) below the grab bar (2010 ADA Fig 604.7 and 609.3)
ACS	0202	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Third Accessible Restroom (From Right to Left) in Day Room 1	Toilet tissue dispenser is mounted 6.5" (165 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser we recommend mounting 1.5" (38 mm) below the grab bar (2010 ADA Fig 604.7 and 609.3)
ACS	0214	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Fourth Accessible Restroom (From Right to Left) in Day Room 1	Toilet tissue dispenser is mounted 6" (152 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser we recommend mounting 1.5" (38 mm) below the grab bar (2010 ADA Fig 604.7 and 609.3)
ACS	0231	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	First Accessible Restroom (From Left to Right) in Day Room 2	Toilet tissue dispenser is mounted 7.75" (197 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser we recommend mounting 1.5" (38 mm) below the grab bar (2010 ADA Fig 604.7 and 609.3)
ACS	0254	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0260	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Ambulatory accessible compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.2.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0261	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0328	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Accessible Route Leading to Building B	Bench is mounted at 16" (406 mm) above the finished floor.	§903.5	We recommend providing a new bench mounted 17-19" (431mm-485 mm) above the finished floor seat height with armrests and supportive backrest design (for ease in sitting/standing) (2010 ADA Fig.903.4).
ACS	*0253	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Women's Accessible Locker Room No. 526	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0042	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0006	1st	COM SPC	Art Room No. 507 (Building B)	This room was busy at time of survey therefore it was not surveyed.	N/A	This room was busy at time of survey therefore it was not surveyed.
ACS	0144	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258		1st	COM SPC	Auto Tag Office (Building B)	The auto tag office was closed at the time of survey, therefore it was not surveyed.	N/A	The auto tag office was closed at the time of survey, therefore it was not surveyed.
ACS	0174	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0037	1st	COM SPC	Quiet Room No. 619	This room was locked at time of survey, therefore it was not inspected	N/A	This room was locked at time of survey, therefore it was not inspected
ACS	0248	Senior Services	Dorothy C Benson Senior Multipurpose	6500 Vernon Woods Dr NE Atlanta, GA 303258	0051	1st	COM SPC	Fourth Accessible Restroom (From Left to Right) in Day Room 2	This restroom was locked at time of survey, therefore it was not inspected.	N/A	This restroom was locked at time of survey, therefore it was not inspected.
ACS	0006	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Main Entrance	Mat is not securely attached to the floor.	§302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).
ACS	0001	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0001	1st	COM SPC	Accessible Route from Public Rights-of-Way Leading to Main Entrance (On Fairburn Rd NW)	There is no signage posted indicating the location of an accessible entrance.	§216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).
ACS	0002	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route from Public Rights-of-Way Leading to Main Entrance (On Fairburn Rd NW)	Gate does not provide the required maneuvering clearance on the pull side.	§404.2.4	Rework slab in front of gate to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0003	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route from Public Rights-of-Way Leading to Main Entrance (On Fairburn Rd NW)	Gate has non-compliant hardware, requiring grasping and turning of the wrist to operate.	§404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0004	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route from Public Rights-of-Way Leading to Main Entrance (On Fairburn Rd NW)	The surface of the accessible route has loose material.	§302.1	Rework and clean sidewalk to provide a stable, firm, and slip-resistant floor surface.
ACS	0005	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0002	1st	COM SPC	Main Entrance	Accessible entrance does not have signage displaying the international symbol of accessibility.	§216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0007	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0003	1st	COM SPC	Men's Accessible Restroom by Lobby	Permanent room identifying signage is mounted on the hinge side of the door.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0008	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Door has a non-compliant opening force of 12 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0021	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0004	1st	COM SPC	Women's Accessible Restroom by Cafeteria	Permanent room identifying signage is mounted at 63.25" (1607 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0028	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0005	1st	COM SPC	Men's Accessible Restroom by Cafeteria	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0045	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0011	1st	COM SPC	Conference Room A No. C133	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0047	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Conference Room A No. C133	Furniture encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0049	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0013	1st	COM SPC	Resource Room No. C128	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0052	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0014	1st	COM SPC	Lounge Room No. C129	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0053	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0015	1st	COM SPC	Conference Room B No. C134	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0062	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0017	1st	COM SPC	Art Room No. C136	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0073	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0018	1st	COM SPC	Computer Lab Room No. C144	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character. At 60" 91524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0074	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Computer Lab Room No. C144	Computers do not appear to have accessible software.	\$508	Title II of the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic and information technology. Per Section 508 ensure computer provides accessible hardware/software
ACS	0078	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0019	1st	COM SPC	Craft Room No. C144	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character. At 60" 91524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0082	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Craft Room No. C144	Trash bin encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate trash bin to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0083	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0020	1st	COM SPC	Ceramics Room No. C141	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0093	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0022	1st	COM SPC	Activity Room No. C147	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character. Not at 60" (1524 m) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0094	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Activity Room No. C147	Trash bin encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate trash bin to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor area (2010 ADA Fig. 404.2.4.1).
ACS	0095	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Activity Room No. C147	Maneuvering clearance on the pull side of the door is 17.5" (444 mm).	\$404.2.4	Reverse door swing to comply with the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0098	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0023	1st	COM SPC	Emergency Exit by Activity Room No. C147	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0099	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0024	1st	COM SPC	Fitness Room No. C152	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character. Not at 60" (1524 m) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0100	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Fitness Room No. C152	Desk, trash bin and exercise equipment encroach over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate desk, trash bin and exercise equipment to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0106	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0025	1st	COM SPC	Nail Salon Room No. C178	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character. Not at 60" (1524 m) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0110	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Nail Salon Room No. C178	Furniture and equipment encroach over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate furniture and equipment to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor area (2010 ADA Fig. 404.2.4.1).
ACS	0111	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0026	1st	COM SPC	Emergency Exit Sign by Room No. C178	Permanent room identifying signage is mounted on the ceiling.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0112	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0027	1st	COM SPC	Unisex Restroom G5 at Day Room	Permanent room identifying signage is mounted at 63.5" (1613 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to the centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0118	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0028	1st	COM SPC	Unisex Restroom G6 at Day Room	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0125	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G7 at Day Room	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0133	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G8 at Day Room	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0140	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0030	1st	COM SPC	Nurse's Station G185 at Day Room	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character. Not at 60" (1524 m) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0141	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Nurse's Station G185 at Day Room	Equipment encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate equipment to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area(2010 ADA Fig. 404.2.4.1).
ACS	0142	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Nurse's Station G185 at Day Room	Equipment encroaches over hand sanitizer clear floor space.	\$305.3	Relocate hand sanitizer to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at hand sanitizer (2010 ADA Figs. 305.3-305.5).
ACS	0146	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0032	1st	COM SPC	Restroom No. G4 at Adult Day Room No. 2	Signage containing tactile characters does not have the required clear floor space due to a planter	\$703.4.2	Relocate planter to ensure that a clear floor space of 18" (455 mm) min. by 18" (455 mm) min. centered on the tactile characters, is provided beyond the arc of the door swing, between the closed position and 45° open position (2010 ADA Fig.703.4.2).
ACS	0147	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G4 at Adult Day Room No. 2	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. At 60" (1254 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0155	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0033	1st	COM SPC	Restroom No. G3 at Adult Day Room No. 2	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. At 60" (1254 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0162	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0034	1st	COM SPC	Restroom No. G2 at Adult Day Room No. 2	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0169	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0035	1st	COM SPC	Restroom No. G1 at Adult Day Room No. 2	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0170	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G1 at Adult Day Room No. 2	Door has a non-compliant opening force of 10 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0177	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0036	1st	COM SPC	Adult Day Room No. G194	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline... VERIFY	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0178	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0037	1st	COM SPC	Dining Room No. G208	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0179	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Dining Room No. G208	Furniture and boxes encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0181	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0039	1st	COM SPC	Hair Stylist Room No. G201	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character. Not at 60" 91524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0183	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0040	1st	COM SPC	Therapy Room No. G203	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character. Not at 60" 91524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0186	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Therapy Room No. G203	Furniture encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0187	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0041	1st	COM SPC	Quiet Room No. G204	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character. Not at 60" 91524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0188	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0042	1st	COM SPC	Personal Care Room No. G206	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character. Not at 60" 91524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0205	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0044	1st	COM SPC	Pool Area	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character. Not at 60" 91524 mm) to centerline	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0206	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Maneuvering clearance on the pull side of the door is 15" (381 mm) and it is reduced by a partition in front of the door	§404.2.4	Install an automatic door opener to comply with requirements for 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0207	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Secondary door has a maneuvering clearance on the pull side of the door of 15.75" (400 mm).	§404.2.4	Reverse door swing or install an automatic door opener to comply with requirements for a 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0208	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Door has a non-compliant opening force of 14 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0212	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Pool handrails have a clear width greater than 24" (610 mm) between the handrails	§1009.6.1	Rework handrails to provide a clear width between 20" and 24" (510 mm - 610 mm) max. This is a secondary means of entry to pool, no remedial work is necessary
ACS	0213	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Pool lift is mounted at 11" (279 mm) from the edge of the pool.	§1009.2.2	Provide a pool lift that when in raised position the centerline of the seat is located over the deck and 16" (405 mm) min. from the edge of the pool (2010 ADA Fig. 1009.2.2).
ACS	0214	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Sloped entry to pool only has handrails on one side, and/or handrails do not have extensions.	§1009.3.3	Install handrails on both sides of sloped entry to pool and mount between 34" and 38" (863 mm - 965 mm) above the finished floor to top of gripping surface. Handrails shall extend 12" (304 mm) min. beyond the top of the ramp segment (2010 ADA Fig. 505.1)
ACS	0215	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Pool lift mechanism is not capable of unassisted operation from the deck and water levels. (does not provide a remote control)	§1009.2.7	Provide a pool lift that is capable of unassisted operation from the deck and water levels.
ACS	0216	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Armrest positioned opposite to the water is not mounted on lift and/or is missing.	§1009.2.6	Provide a pool lift seat that has removable armrest or armrests that fold clear of the seat when the seat is in the raised (load) position.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0217	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Pool lift mechanism encroaches the clear deck space required on the side of the seat opposite to the water.	\$1009.2.3	Install a new pool lift that allows a clear deck space parallel to the seat that is 36" (915 mm) min. wide, and extends forward 48" (1220 mm) min. from a line located 12" (305 mm) behind the rear edge of seat and slopes below 2% (2010 ADA Fig. 1009.2.3).
ACS	0219	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0045	1st	COM SPC	Women's Locker Room D	Permanent room identifying signage is mounted at 63.5" (1613 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to the centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0242	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0048	1st	COM SPC	Door at Women's Restroom Leading to Pool Area	Permanent room identifying signage is mounted at 63" (1600 mm) to the baseline of the highest tactile character. Not at 60" (1524 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0243	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Door at Women's Restroom Leading to Pool Area	Partition encroaches into maneuvering clearance on the pull side of the door reducing it to 14" (356 mm).	\$404.2.4	Install an automatic door opener to comply with the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0244	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Door at Women's Restroom Leading to Pool Area	Door has a non-compliant opening force of 8 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0245	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Door at Women's Restroom Leading to Pool Area	Secondary door has a maneuvering clearance on the pull side of the door of 15" (381 mm).	\$404.2.4	Install an automatic door opener to comply with requirements for a 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0246	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Door at Women's Restroom Leading to Pool Area	Door has a non-compliant opening force of 12 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0247	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0049	1st	COM SPC	Passenger Loading Zone by Main Entrance	Passenger loading zone does not have signage displaying the international symbol of accessibility.	\$503	Provide signage displaying the international symbol of accessibility at passenger loading zone.
ACS	0250	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0051	Grade	COM SPC	Two Accessible Parking Spaces on Left Side of Adult Day Care Entrance	Accessible parking space on left has signage indicating accessible parking mounted at 49.75" (1264 mm) above the finished floor.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.
ACS	0251	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Accessible Parking Spaces on Left Side of Adult Day Care Entrance	Accessible parking space on right has signage indicating accessible parking mounted at 56.25" (1429 mm) above the finished floor.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0252	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Accessible Parking Spaces on Left Side of Adult Day Care Entrance	Accessible parking space on left is not clearly outlined or need re-striping.	\$502.3.1	Restripe to provide an accessible parking space 96" (2438 mm) min. wide and a 60" (15258 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.3). Van-accessible parking spaces must be 96" (2438 mm) min. wide with a 96" (2438 mm) min. wide
ACS	0253	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Accessible Parking Spaces on Left Side of Adult Day Care Entrance	Accessible parking space on right is not clearly outlined or need re-striping.	\$502.3.1	Restripe to provide an accessible parking space 96" (2438 mm) min. wide and a 60" (15258 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.3).
ACS	0254	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0052	1st	COM SPC	Accessible Route Leading to Adult Day Care Entrance	Ramp has a non-compliant cross slope of 6.1 %.	\$405.3	Rework ramp to provide a cross slope not exceeding 2 %.
ACS	0255	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route Leading to Adult Day Care Entrance	Accessible route has a non-compliant cross slope of 3.3 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0256	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route Leading to Adult Day Care Entrance	Accessible route has a non-compliant cross slope of 2.4 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0257	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route Leading to Adult Day Care Entrance	Accessible route has a non-compliant cross slope of 6.1 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0258	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route Leading to Adult Day Care Entrance	Accessible route has a non-compliant cross slope of 5.8 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0259	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0053	1st	COM SPC	Adult Day Care Entrance	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.
ACS	0260	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0054	Grade	COM SPC	Two Accessible Parking Spaces on Right Side of Adult Day Care Entrance	Accessible parking space is not clearly outlined in blue or needs re-striping.	\$502.3.1	Restripe to provide an accessible parking space 96" (2438 mm) min. wide and a 60" (15258 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.3).
ACS	0264	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Accessible Parking Spaces on Right Side of Adult Day Care Entrance	Accessible parking space on left has signage mounted at 58.5" (1486 mm) above the finished floor.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.
ACS	0265	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Accessible Parking Spaces on Right Side of Adult Day Care Entrance	Accessible parking space on left has signage mounted at 49" (1245 mm) above the finished floor.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.

Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0266	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0056	1st	COM SPC	Accessible Route Leading to Adult Day Care Entrance (South Entrance)	Curb ramp has a 9.9 % non-compliant running slope.	§406	Rework curb ramp to provide a running slope not to exceed 8.33%
ACS	0267	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route Leading to Adult Day Care Entrance (South Entrance)	Curb ramp has a 6.2 % non-compliant cross slope.	§406.1	Rework curb ramp to provide a cross slope not to exceed 2%.
ACS	0268	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0057	1st	COM SPC	Passenger Loading Zone by Adult Day Care Entrance (South Side)	Passenger loading zone does not have signage displaying the international symbol of accessibility.	§503	Provide signage displaying the International symbol of accessibility at passenger loading zone.
ACS	0270	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Passenger Loading Zone by Adult Day Care Entrance (South Side)	Transition from sidewalk to passenger loading zone has an opening that is 1" (25 mm) wide.	§302.3	Rework floor grate to provide a 0.5" (12 mm) max. wide opening perpendicular to the dominant direction of travel (2010 ADA Fig.302.3).
ACS	0271	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Passenger Loading Zone by Adult Day Care Entrance (South Side)	Accessible route has a 1" (25 mm) vertical change in level transition from sidewalk to gutter at passenger loading zone	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 (2010 ADA Fig. 303.3).
ACS	0273	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0058	1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Curb ramp on left side has a 11.7 % non-compliant running slope.	§406	Rework curb ramp to provide a running slope not to exceed 8.33%
ACS	0274	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Curb ramp has a 4.6 % non-compliant cross slope.	§406.1	Rework curb ramp to provide a cross slope not to exceed 2%.
ACS	0275	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a 0.5" (13 mm) vertical change in level that is not beveled.	§403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 (2010 ADA Fig. 303.3).
ACS	0276	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Curb ramp has a 9.5 % non-compliant running slope.	§406	Rework curb ramp to provide a running slope not to exceed 8.33%
ACS	0277	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 6.4 % that extends 10 ft (3.04 mt).	§403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0278	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has an opening that is 1" (25 mm) wide.	§302.3	Rework floor grate to provide a 0.5" (12 mm) max. wide opening perpendicular to the dominant direction of travel (2010 ADA Fig.302.3).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0279	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 3.2 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0280	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 2.9 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0281	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 3.4 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0282	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 5.5 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0283	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 5.2 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0284	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 4.0 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0285	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 3.7 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0286	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 2.7 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0287	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 3.2 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.

Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0288	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces on South Side Leading to Main Entrance (West Entrance)	Accessible route has a non-compliant cross slope of 2.3 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0289	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0059	Grade	COM SPC	Three Accessible Parking Spaces on East Side of Building	The accessible parking spaces are not clearly outlined or needs re-striping.	\$502.3.1	Restripe to provide an accessible parking space 96" (2438 mm) min. wide and a 60" (15258 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.3).
ACS	0290	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Three Accessible Parking Spaces on East Side of Building	First accessible parking space from left to right does not have signage indicating the penalty for illegal use of the parking space.	\$502.6	Install sign indicating accessible parking displaying the international symbol of accessibility, bearing the caption "Parking by disabled Permit only" and the penalty for illegal use of this space, and mount at 60" (1524 mm) min. above the finish floor
ACS	0292	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Three Accessible Parking Spaces on East Side of Building	First accessible parking space does not have an access aisle.	\$502.3.1	Rework area to provide an accessible parking space with a corresponding 60" (1524 mm) min. wide access aisle (2010 ADA Fig. 502.3).
ACS	0294	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Three Accessible Parking Spaces on East Side of Building	Second accessible parking space from left to right does not have signage indicating the penalty for illegal use of the parking space.	\$502.6	Install sign indicating accessible parking displaying the international symbol of accessibility, bearing the caption "Parking by disabled Permit only" and the penalty for illegal use of this space, and mount at 60" (1524 mm) min. above the finish floor
ACS	0295	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Three Accessible Parking Spaces on East Side of Building	Second accessible parking space from left to right does not have an access aisle.	\$502.3.1	Restripe to provide an accessible parking space with a corresponding 60" (1524 mm) min. wide access aisle (2010 ADA Fig. 502.3).
ACS	0296	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Three Accessible Parking Spaces on East Side of Building	Third accessible parking space from left to right does not have signage indicating the penalty for illegal use of the parking space.	\$502.6	Install sign indicating accessible parking displaying the international symbol of accessibility, bearing the caption "Parking by disabled Permit only" and the penalty for illegal use of this space, and mount at 60" (1524 mm) min. above the finish floor
ACS	0298	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0060	Grade	COM SPC	Two Additional Accessible Parking Spaces on East Side of Building	First accessible parking space from left to right is mounted at 53.75" (1365 mm) above the finished floor.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.
ACS	0301	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Additional Accessible Parking Spaces on East Side of Building	Second accessible parking space from left to right does not have signage indicating the penalty for illegal use of the parking space.	\$502.6	Install sign indicating accessible parking displaying the international symbol of accessibility, bearing the caption "Parking by disabled Permit only" and the penalty for illegal use of this space, and mount at 60" (1524 mm) min. above the finish floor
ACS	0303	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0061	1st	COM SPC	Accessible Route From Accessible Parking Spaces Leading to East Side Entrance to Building	The transition from the access aisle to the concrete has an opening that is 1.5" (38 mm) wide.	\$302.3	Rework area to provide a 0.5" (12 mm) max. wide opening perpendicular to the dominant direction of travel (2010 ADA Fig.302.3).
ACS	0304	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Accessible Route From Accessible Parking Spaces Leading to East Side Entrance to Building	There is no signage posted indicating the location of an accessible entrance.	\$216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0305	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0062	1st	COM SPC	East Side Entrance to Building	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.
ACS	0306	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0063	1st	COM SPC	East Side Entrance to Pool Area	Maneuvering clearance on the pull side of the door has non-compliant slope of 3.6%.	\$404.2.4	Rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0307	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	East Side Entrance to Pool Area	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.
ACS	*0248	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Passenger Loading Zone by Main Entrance	Passenger loading zone has a non-compliant surface slope of up to 3.9% at access aisle.	\$503.4	We recommend painting the passenger loading zone and access aisle over the asphalt, to avoid remedial work on concrete. The passenger loading zone must be striped to provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).
ACS	*0261	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0055	Grade	COM SPC	Two Accessible Parking Spaces on Right Side of Adult Day Care Entrance	Accessible parking space on right has a non-compliant surface slope of up to 3.2%	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0262	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Accessible Parking Spaces on Right Side of Adult Day Care Entrance	Access aisle has a non-compliant surface slope of up to 4.4%	\$502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.
ACS	*0263	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Accessible Parking Spaces on Right Side of Adult Day Care Entrance	Accessible parking space on right has a non-compliant surface slope of up to 3.0%	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0269	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Passenger Loading Zone by Adult Day Care Entrance (South Side)	Passenger loading zone has a non-compliant surface slope of up to 2.3%	\$503.4	Restripe to provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).
ACS	*0272	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Passenger Loading Zone by Adult Day Care Entrance (South Side)	Passenger loading zone has a non-compliant surface slope of up to 3.5%	\$503.4	Restripe to provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).
ACS	*0291	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Three Accessible Parking Spaces on East Side of Building	First accessible parking space from left to right has a non-compliant running slope of up to 6.5%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	*0293	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Three Accessible Parking Spaces on East Side of Building	Second accessible parking space from left to right has a non-compliant running slope of up to 5.5%	§504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0297	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Three Accessible Parking Spaces on East Side of Building	Third accessible parking space from left to right has a non-compliant running slope of up to 5.8%	§504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0299	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Additional Accessible Parking Spaces on East Side of Building	First accessible parking space from left to right has a non-compliant running slope of up to 5.8%	§504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0300	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Additional Accessible Parking Spaces on East Side of Building	Access aisle has a 5.8 % non-compliant running slope.	§502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.
ACS	*0302	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		Grade	COM SPC	Two Additional Accessible Parking Spaces on East Side of Building	Second accessible parking space from left to right has a non-compliant running slope of up to 5.7%	§504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0009	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter. <i>This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0010	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Soap dispenser is mounted at 47" (1194 mm) above the finished floor over and obstruction (counter)	§308.2.2	Lower or install at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction, for a forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0011	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Stall door swings into hand dryer clear floor space.	§305.3	Install dual action hinges on stall door to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at hand dryer (2010 ADA Figs. 305.3-305.5).
ACS	0013	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Accessible toilet compartment (stall) door is located at 5.5" (140 mm) from the side wall or partition farthest from the water closet	§604.8.1.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the side wall or partition farthest from the water closet (For door located in front of partition) (2010 ADA Fig. 604.8.1.1)

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0014	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Water closet is centered at 18.25" (464 mm) from side wall	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). <i>This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0015	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Water closet seat is mounted at 19.5" (495 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0016	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Locker requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0017	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Transfer shower controls and spray hose are not mounted on the control area (they are mounted on the back wall)	§608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.
ACS	0018	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Transfer shower controls are mounted 61" (1549 mm) above the finished floor to the centerline	§608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.
ACS	0019	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Transfer shower stall is 34" (864 mm) wide by 36.25" (921 mm) deep.	§608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1).
ACS	0020	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Transfer shower has an L-shaped seat with the front edge mounted at 16.25" (405 mm) max. from the seat wall, and the end of the "L" shape is mounted is mounted at 23.25" (585 mm) from main seat wall.	§608.4	Install L-shaped seat with the front edge mounted at 15"-16" (380 mm - 405 mm) max. from the wall, the end of the "L" shape shall be 22"-23" (560 mm - 585 mm) max. from the main seat wall and the front edge of the "L" portion 14"-15" (355 mm - 380 mm) max. from the wall.
ACS	0022	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Accessible Restroom by Cafeteria	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter. <i>This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0023	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Accessible Restroom by Cafeteria	Water closet has the rear wall grab bar mounted at 23" (584 mm) perpendicular from the water closet centerline to the outer flange (open side) of the grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0024	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Accessible Restroom by Cafeteria	Water closet is centered at 19.25" (489 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0025	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Accessible Restroom by Cafeteria	Water closet seat is mounted at 20" (508 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0026	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Accessible Restroom by Cafeteria	Accessible toilet compartment (stall) door is located at 6.75" (171 mm) from the side wall or partition farthest from the water closet	§604.8.1.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the side wall or partition farthest from the water closet (For door located in front of partition) (2010 ADA Fig. 604.8.1.1)
ACS	0027	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Accessible Restroom by Cafeteria	Hand dryer protrudes into walkway, projecting 8" (203 mm) from back wall, and is mounted at 45.25" (1149 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate or recess hand dryer so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).
ACS	0030	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Cafeteria	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 62.25" (1581 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0031	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Cafeteria	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). <i>This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0032	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Cafeteria	Water closet seat is mounted at 20" (508 mm) above the finished floor to top.	§604.2	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0033	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Cafeteria	Water closet side wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0034	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Cafeteria	Urinal is mounted in a 35" (35 mm) wide and 60.75" (889 mm) deep alcove.	§605.3	Remove/relocate partitions to provide a 36" (914 mm) min. wide alcove for a forward approach to object (2010 ADA Fig. 305.7.1). <i>Per 2010 ADA section 213.3 urinals are only required to comply with section 605 where more than one urinal is provided.</i>
ACS	0035	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Cafeteria	Urinal is mounted at 17.5" (444 mm) above the finished floor to top of rim.	§605.2	Lower urinal and mount at 17" (431 mm) max. above the finished floor to top of rim. (2010 ADA Fig. 605.2). <i>Per 2010 ADA section 213.3 urinals are only required to comply with section 605 where more than one urinal is provided.</i>
ACS	0036	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Cafeteria	Hand dryer protrudes into walkway, projecting 8.5" (216 mm) from back wall, and is mounted at 45.25" (1149 mm) above the finished floor to its bottom leading edge.	§307.2r	Relocate or recess so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0037	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0006	1st	COM SPC	Coat Storage by Dining Area	Clothes rod is mounted beyond required reach allowed for approach provided and is mounted at 63.5" (1613 mm) above the finished floor.	§308.2.1	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0038	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Coat Storage by Dining Area	Shelf is mounted beyond required reach range for approach provided and is mounted at 66" (1676 mm) above the finished floor.	§308.2.1	Lower or install accessible shelf at 48" (1219 mm) max. above the finished floor (2010 ADA Fig. 308.3.1).
ACS	0039	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0007	1st	COM SPC	Dining Area	Tables have a non-compliant 14.5" (368 mm) horizontal projection due to pedestal base.	§902.2	Replace tables to provide 5% accessible seating spaces with the table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(4) and 306.3 (a)(4)).
ACS	0040	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Dining Area	Tray slide surface is mounted at 35.25" (895 mm) above the finished floor.	§902.3	Rework to provide the top of the tray slide surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.
ACS	0041	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Dining Area	Electronic hand sanitizer is mounted beyond required reach allowed for approach provided and is mounted at 56" (1422 mm) above the finished floor to the dispenser outlet	§308.2.1	Lower or install electronic hand sanitizer at 48" (1219 mm) max. above the finished floor to the dispenser outlet (2010 ADA Fig. 308.2.1).
ACS	0042	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0008	1st	COM SPC	Accessible Route Leading to Stage Area (Ramp_	Equipment encroaches passage width reducing it to less than 36" (914 mm).	§403.5.1	Relocate equipment to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).
ACS	0043	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0009	1st	COM SPC	Outdoor Seating Area	Bench is mounted at 20.5" (521 mm) above the finished floor.	§903.5	We recommend reworking bench to provide 17-19" (431mm-485 mm) above the finished floor seat height with armrests and supportive backrest design (for ease in sitting/standing) (2010 ADA Fig.903.4).
ACS	0044	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0010	1st	COM SPC	Hallway Leading to Classrooms	Hand sanitizer protrudes into walkway, projecting 5" (127 mm) from back wall, and is mounted at 46.25" (1175 mm) above the finished floor to its bottom leading edge.	§307.2	Relocate or recess hand sanitizer so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).
ACS	0046	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Conference Room A No. C133	Hand sanitizer dispenser is mounted beyond required reach allowed for approach provided and is mounted at 55.5" (1410 mm) above the finished floor.	§308.2.1	Lower or install hand sanitizer dispenser at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0048	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0012	1st	COM SPC	Corridor by Resource Room No. C128	Brochure rack is mounted at 74" (1880 mm) above the finished floor to highest shelf.	§308.2.1	Lower or install brochure rack at 48" (1219 mm) max. above the finished floor to highest shelf (2010 ADA Fig. 308.2.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0050	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Resource Room No. C128	TV does not have the closed caption unit turned on.	\$36.303 (e)	Implement a policy to have the closed caption feature on during business hours.
ACS	0051	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Resource Room No. C128	Furniture encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0054	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Conference Room B No. C134	Hand sanitizer is mounted beyond required reach allowed for approach provided and is mounted at 57.75" (1467 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install at hand sanitizer 48" (1219 mm) max. above the finished floor to the highest operable part. (2010 ADA Fig. 308.2.1).
ACS	0055	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0016	1st	COM SPC	Unisex Accessible Restroom by Room No. C130	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0056	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Accessible Restroom by Room No. C130	Lavatory is mounted at 55" (1397 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$604.3.1	Reconfigure restroom's fixtures and/or urinal partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the 2010 Standards.
ACS	0057	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Accessible Restroom by Room No. C130	Water closet has the rear wall grab bar mounted at 19.5" (495 mm) perpendicular from the water closet centerline the outer flange (open side) of the grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar. Mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0058	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Accessible Restroom by Room No. C130	Water closet side wall grab bar is mounted at 53.5" (1359 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0059	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Accessible Restroom by Room No. C130	Toilet seat cover dispenser is mounted 2.5" (64 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0060	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Accessible Restroom by Room No. C130	Toilet tissue dispenser is mounted at 15.25" (387 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall and mount at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0061	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Accessible Restroom by Room No. C130	Trash bin encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate trash bin to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).
ACS	0063	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Art Room No. C136	Chair encroaches over hand sanitizer, light switch and thermostat clear color space clear floor space.	§305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at hand sanitizer (2010 ADA Figs. 305.3-305.5).
ACS	0064	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Art Room No. C136	Hand sanitizer is mounted beyond required reach allowed for approach provided and is mounted at 50.5" (1283 mm) above the finished floor.	§308.2.1	Lower or install hand sanitizer at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>
ACS	0065	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Art Room No. C136	Light switch is mounted at 55.25" (1403 mm) above the finished floor to the highest operable part.	§308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0066	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Art Room No. C136	Table encroaches over telephone clear floor space.	§305.3	Relocate table to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at telephone (2010 ADA Figs. 305.3-305.5).
ACS	0067	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Art Room No. C136	Table encroaches over sink clear floor space.	§305.3	Relocate table to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at sink (2010 ADA Figs. 305.3-305.5).
ACS	0068	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Art Room No. C136	Sink has unwrapped bottom pipes.	§804.4	Cover (insulate) sink bottom supply and drain pipes.
ACS	0069	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Art Room No. C136	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.
ACS	0070	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Art Room No. C136	Wall cabinets over the work surface are mounted at 59.75" (1518 mm) above the finished floor to the bottom shelf.	§804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.
ACS	0071	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Art Room No. C136	Telephone is mounted at 60.25" (1530 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0072	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Art Room No. C136	Shelf is mounted beyond required reach range for approach provided and is mounted at 51" (1295 mm) above the finished floor.	§308.2.1	Lower or install accessible shelf at 48" (1219 mm) max. above the finished floor for forward or side approach (2010 ADA Fig. 308.3.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0075	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Computer Lab Room No. C144	Planter encroaches over hand sanitizer clear floor space.	§305.3	Relocate planter to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at hand sanitizer (2010 ADA Figs. 305.3-305.5).
ACS	0076	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Computer Lab Room No. C144	Planter encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate planter to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0077	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Computer Lab Room No. C144	Hand sanitizer is mounted at 50" (1270 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install hand sanitizer at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0079	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Craft Room No. C144	Chairs and desk encroach over sink clear floor space.	§305.3	Relocate chairs and desk to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at sink (2010 ADA Figs. 305.3-305.5).
ACS	0080	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Craft Room No. C144	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter. This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0081	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Craft Room No. C144	Wall cabinets over the work surface are mounted at 58.75" (1492 mm) above the finished floor to the bottom shelf.	§804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.
ACS	0084	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Ceramics Room No. C141	Equipment encroaches over thermostat, telephone and hand sanitizer clear floor space.	§305.3	Relocate equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space for thermostat, telephone and hand sanitizer (2010 ADA Figs. 305.3-305.5).
ACS	0085	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Ceramics Room No. C141	Equipment encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate equipment to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0086	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Ceramics Room No. C141	Telephone is mounted at 59.75" (1518 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0087	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Ceramics Room No. C141	Hand sanitizer is mounted at 61" (1549 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install hand sanitizer at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0088	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Ceramics Room No. C141	Sink has unwrapped bottom pipes.	§804.4	Cover (insulate) sink bottom supply and drain pipes.
ACS	0089	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Ceramics Room No. C141	Sink is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3.2	Relocate or rework sink and mount at 34" (865 mm) max. above the finished floor to top of counter. <i>This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerances.</i>
ACS	0090	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Ceramics Room No. C141	Wall cabinets over the work surface are mounted at 59" (1499 mm) above the finished floor to the bottom shelf.	§804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.
ACS	0091	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Ceramics Room No. C141	Paper towel dispenser is at 46.25" (1175 mm) above the finished floor over an obstruction (sink counter)	§308.2.2	Lower or install at 44" (1219 mm) max. above the finished floor, over a 20" - 25" (510 mm - 1120 mm) max. obstruction, for a forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0092	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0021	1st	COM SPC	Corridor by Ceramics Room No. C141	Hand sanitizer protrudes into walkway, projecting 4" (102 mm) from back wall, and is mounted at 48" (1219 mm) above the finished floor to its bottom leading edge.	§308.2.1	Relocate or recess hand sanitizer so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).
ACS	0096	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Activity Room No. C147	TV does not have the closed caption unit turned on.	§36.303(e)	Implement a policy to have the closed caption feature on during business hours.
ACS	0097	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Activity Room No. C147	Light switch is mounted at 50.5" (1283 mm) above the finished floor to the highest operable part.	§308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the...</i>
ACS	0101	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Fitness Room No. C152	Trash bin and exercise equipment encroach over hand sanitizer clear floor space.	§305.3	Relocate trash bin and exercise equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0102	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Fitness Room No. C152	Hand sanitizer is mounted at 56.25" (1429 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install hand sanitizer at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0103	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Fitness Room No. C152	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 71.5" (1816 mm) above the finished floor.	§308.2.1	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object
ACS	0104	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Fitness Room No. C152	Exercise machines and equipment have a non-compliant clear floor space.	§1004.1	Relocate exercise machines and equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space, positioned for transfer or use by an individual seated in a wheelchair (2010 ADA Fig. 305.3, 305.5).
ACS	0105	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Fitness Room No. C152	Accessible route inside the fitness room has a non-compliant clear width that is less than 36" (914 mm) due to exercise equipment	§403.5.1	Relocate exercise equipment to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0107	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Nail Salon Room No. C178	Furniture and equipment encroaches passage width reducing it to less than 36" (914 mm).	§403.5.1	Relocate furniture and equipment to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).
ACS	0108	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Nail Salon Room No. C178	Furniture and equipment encroaches over pedicure chair clear floor space.	§305.3	Relocate pedicure chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0109	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Nail Salon Room No. C178	Furniture and equipment encroach into the required diameter wheelchair turnaround space.	§304.3	Relocate furniture and equipment to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2).
ACS	0113	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G5 at Day Room	Sink is mounted at 34.5" (876 mm) above the finished floor to the top.	§606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.
ACS	0114	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G5 at Day Room	Water closet has a 24" (610 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0115	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G5 at Day Room	Lavatory is mounted at 35" (889 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	§4.19.2 §604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2 conduct barrier removal to the maximum extent feasible within the existing footprint and relocate lavatory at 36" (914 mm) min. from water closet side wall to outer leading edge of lavatory (2010 ADA Fig. 28).
ACS	0116	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G5 at Day Room	Water closet seat is mounted at 20" (508 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0117	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G5 at Day Room	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 66" (1676 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0119	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G6 at Day Room	Water closet side wall grab bar is mounted at 47" (1194 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface. (2010 ADA Fig. 604.5.1).
ACS	0120	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G6 at Day Room	Nurse call button is mounted beyond required reach allowed for approach provided and is mounted at 49" (1245 mm) above the finished floor to the centerline	\$308.2.1	Lower or install nurse call button at 48" (1219 mm) max. above the finished floor to the centerline for forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order. Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2 conduct barrier removal to the maximum extent feasible within the existing footprint and relocate lavatory at 36" (914 mm) min. from water closet side wall to outer leading
ACS	0121	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G6 at Day Room	Lavatory is mounted at 34.5" (876 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$4.19.2 \$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2 conduct barrier removal to the maximum extent feasible within the existing footprint and relocate lavatory at 36" (914 mm) min. from water closet side wall to outer leading
ACS	0122	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G6 at Day Room	Water closet is centered at 18.75" (476 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0123	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G6 at Day Room	Water closet has a 24" (610 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig. 604.5.2).
ACS	0124	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G6 at Day Room	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 66" (1676 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0126	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G7 at Day Room	Water closet has a 24" (610 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig. 604.5.2).
ACS	0127	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G7 at Day Room	Lavatory is mounted at 34.5" (876 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$4.19.2 \$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2 conduct barrier removal to the maximum extent feasible within the existing footprint and relocate lavatory at 36" (914 mm) min. from water closet side wall to outer leading edge of lavatory (2010 ADA Fig. 28).
ACS	0128	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G7 at Day Room	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0129	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G7 at Day Room	Water closet seat is mounted at 21.25" (540 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0130	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G7 at Day Room	Water closet side wall grab bar is mounted at 50" (1270 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface. (2010 ADA Fig. 604.5.1).
ACS	0131	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G7 at Day Room	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 66.25" (1683 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0132	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0029	1st	COM SPC	Unisex Restroom G8 at Day Room	Boxes and shelf encroach over the required sign clear floor space.	§703.4.2	Relocate shelf and box to ensure that a clear floor space of 18" (455 mm) min. by 18" (455 mm) min. centered on the tactile characters, is provided beyond the arc of the door swing, between the closed position and 45° open position (2010 ADA Fig.703.4.2).
ACS	0134	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G8 at Day Room	Shelf and boxes encroach over maneuvering clearance on the push side of the door.	§404.2.4	Relocate shelf to provide the required 12" (304 mm) min. maneuvering clearance on the push side of the door handle side (2010 ADA Fig. 404.2.4.1).
ACS	0135	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G8 at Day Room	Water closet has a 24" (610 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0136	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G8 at Day Room	Lavatory in stall is mounted at 34.75" (883 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	§4.19.2 §604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2
ACS	0137	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G8 at Day Room	Water closet seat is mounted at 20" (508 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0138	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G8 at Day Room	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 66" (1676 mm) above the finished floor.	§308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0139	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Unisex Restroom G8 at Day Room	Clear floor space is 59.75" (1518 mm) wide and does not provide the required diameter wheelchair turnaround space in room.	§304.3	Reconfigure room's fixtures and/or offset partitions to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space (2010 ADA Fig. 304.3.2). This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0143	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0031	1st	COM SPC	Adult Day Room No. 2	TV does not have the closed caption feature turned on.	§36.303(e)	Implement a policy to have the closed caption feature on during business hours.
ACS	0144	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Adult Day Room No. 2	Clothes rod is mounted beyond required reach allowed for approach provided and is mounted at 63" (1600 mm) above the finished floor.	§308.2.1	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0145	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Adult Day Room No. 2	Shelf is mounted at 66" (1676 mm) above the finished floor to the top.	§308.2.1	Lower or install shelf at 48" (1219 mm) max. above the finished floor to the top (2010 ADA Fig. 308.2.1).
ACS	0148	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G4 at Adult Day Room No. 2	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter. This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0149	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G4 at Adult Day Room No. 2	Water closet has a 24" (610 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0150	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G4 at Adult Day Room No. 2	Lavatory in stall is mounted at 34.5" (876 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$4.19.2 §604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2 conduct barrier removal to the maximum extent feasible within the existing footprint and relocate lavatory at 36" (914 mm) min. from water closet side wall to outer leading edge.
ACS	0151	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G4 at Adult Day Room No. 2	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0152	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G4 at Adult Day Room No. 2	Water closet seat is mounted at 21.5" (546 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0153	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G4 at Adult Day Room No. 2	Nurse call button is mounted beyond required reach allowed for approach provided and is mounted at 50" (1270 mm) above the finished floor to the centerline.	\$308.2.1	Lower or install nurse call button at 48" (1219 mm) max. above the finished floor to the centerline for forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(I) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements
ACS	0154	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G4 at Adult Day Room No. 2	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 66" (1676 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0156	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G3 at Adult Day Room No. 2	Nurse call button is mounted beyond required reach allowed for approach provided and is mounted at 51.5" (1308 mm) above the finished floor.	\$308.2.1	Lower or install nurse call button at 48" (1219 mm) max. above the finished floor to the centerline for forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(I) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0157	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G3 at Adult Day Room No. 2	Water closet side wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.
ACS	0158	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G3 at Adult Day Room No. 2	Water closet has a 24" (610 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0159	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G3 at Adult Day Room No. 2	Water closet seat is mounted at 20.5" (521 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0160	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G3 at Adult Day Room No. 2	Lavatory in stall is mounted at 35.25" (895 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$4.19.2 §604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2 conduct barrier removal to the maximum extent feasible

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0161	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G3 at Adult Day Room No. 2	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 66" (1676 mm) above the finished floor.	§308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0163	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G2 at Adult Day Room No. 2	Nurse call button is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor to the centerline.	§308.2.1	Lower or install nurse call button at 48" (1219 mm) max. above the finished floor to the centerline for forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order
ACS	0164	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G2 at Adult Day Room No. 2	Water closet side wall grab bar is mounted at 50" (1270 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0165	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G2 at Adult Day Room No. 2	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar that extends 24"(610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the floor to top of the gripping surface (2010 ADA Fig 604.5.2)
ACS	0166	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G2 at Adult Day Room No. 2	Lavatory in stall is mounted at 34.5" (876 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	§4.19.2 §604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Element does not comply with 1991 standards section 4.19.2 conduct barrier removal to the maximum extent feasible within the existing footprint and relocate lavatory at 36" (914 mm) min. from water closet side wall to outer leading edge of lavatory (2010 ADA Fig. 28).
ACS	0167	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G2 at Adult Day Room No. 2	Water closet seat is mounted at 20" (508 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0168	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G2 at Adult Day Room No. 2	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 66" (1676 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0171	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G1 at Adult Day Room No. 2	Nurse call button is mounted beyond required reach allowed for approach provided and is mounted at 50.5" (1283 mm) above the finished floor to the centerline.	§308.2.1	Lower or install nurse call button at 48" (1219 mm) max. above the finished floor to the centerline for forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order
ACS	0172	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G1 at Adult Day Room No. 2	Water closet side wall grab bar is mounted at 53.5" (1359 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0173	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G1 at Adult Day Room No. 2	Toilet tissue dispenser is mounted at 15.5" (394 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall and mount at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0174	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G1 at Adult Day Room No. 2	Water closet has a 24" (610 mm) long side wall grab bar.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0175	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G1 at Adult Day Room No. 2	Lavatory in stall is mounted at 36.5" (927 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0176	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Restroom No. G1 at Adult Day Room No. 2	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 66" (1676 mm) above the finished floor.	\$308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0180	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0038	1st	COM SPC	Drinking Fountain by Dining Room No. G208	Low drinking fountain has a 26.75" (679 mm) knee clearance.	\$602.1	Relocate/rework fountain to provide a 27" (685 mm) min. knee clearance above the finished floor, 30" (762 mm) min. wide and 25" (635 mm) max. deep (2010 ADA Fig. 306.3).
ACS	0184	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Therapy Room No. G203	Exercise machines and equipment have a non-compliant clear floor space.	\$1004.1	Relocate exercise machines and equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space, positioned for transfer or use by an individual seated in a wheelchair (2010 ADA Fig. 305.3, 305.5).
ACS	0185	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Therapy Room No. G203	TV does not have the closed caption feature turned on.	\$36.303(e)	Implement a policy to have the closed caption feature on during business hours.
ACS	0189	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Lavatory mirror is mounted at 43" (1092 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0190	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Telephone is mounted at 59.5" (1511 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0191	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Lavatory is mounted at 39" (991 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0192	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Water closet does not have a rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar at 24" (610 mm) min. from water closet centerline to the outer flange (on open side) of the grab bar and 12" (305 mm) min. from the water closet centerline to the inner flange (on wall side) of grab bar, mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2)

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0193	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Water closet has a 18" (457 mm) long side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface. (2010 ADA Fig. 604.5.1)
ACS	0194	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Water closet side wall grab bar is mounted at 20.5" (521 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface. (2010 ADA Fig. 604.5.1)
ACS	0195	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Transfer shower controls and shower head are not mounted on the control area (they are mounted on the back wall)	§608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.
ACS	0196	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Transfer shower stall has a 2" (51 mm) high curb.	§608.7	Rework transfer shower to provide a beveled curb that does not exceed 0.5" (12 mm) in height.
ACS	0197	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Transfer shower grab bar is mounted at a point of 20" (508 mm) from the control wall	§608.3.1	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall; and mount between 33" and 36" (838 mm- 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.608.3.1).
ACS	0198	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Transfer shower controls are mounted 59" (1499 mm) above the finished floor to the centerline	§608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.
ACS	0199	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Transfer shower stall is 35" (889 mm) wide by 37.75" (959 mm) deep.	§608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1).
ACS	0200	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 66" (1676 mm) above the finished floor.	§308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0201	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	First aid kit is mounted beyond required reach allowed for approach provided and is mounted at 66" (1676 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install first aid kit at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0202	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Washer and dryer encroach over lockers clear floor space.	§305.3	Relocate lockers to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0203	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Personal Care Room No. G206	Washer/Dryers have controls mounted on the back of unit.	§611.3	We recommend replacing washer and dryer to provide units with controls mounted on the front panel.
ACS	0204	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0043	1st	COM SPC	Corridor by Administrative Area	Sconce protrudes into walkway, projecting 11" (279 mm) from back wall, and is mounted at 64.5" (1638 mm) above the finished floor to its bottom leading edge.	§307.2r	Relocate or recess sconce so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0209	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Pool equipment and furniture encroach passage width reducing it to less than 36" (914 mm).	§403.5.1	Relocate pool equipment and furniture to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).
ACS	0210	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 69.25" (1759 mm) above the finished floor.	§308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0211	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Shower head is a fixed-type unit.	§608.6	Replace or install additional shower spray unit with a hose that is 59" (1500 mm) min. in length and serves both as a fixed and hand-held unit.
ACS	0218	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Pool Area	Wall/post mounted drinking fountain has a 26.5" (673 mm) knee clearance.	§602.1	Install drinking fountain as to provide a 27" (685 mm) min. knee clearance above the finished floor, 30" (762 mm) min. wide and 25" (635 mm) max. deep (2010 ADA Fig. 306.3).
ACS	0220	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0046	1st	COM SPC	Seating Area by Lobby	Furniture encroaches passage width reducing it to less than 36" (914 mm).	§403.5.1	Relocate furniture to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).
ACS	0221	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0047	1st	COM SPC	Women's Restroom by Lobby	Bench is 18" (457 mm) wide.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.
ACS	0222	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Locker hardware requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0223	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Soap dispenser is mounted at 45" (1143 mm) above the finished floor over 23.5" (597 mm) obstruction (sink counter)	§308.2.2	Lower or install soap dispenser at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction, for a forward approach to object (2010 ADA Fig. 308.2.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0225	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0226	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Toilet tissue dispenser is mounted at 14.5" (368 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall and mount at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).</i>
ACS	0227	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Water closet seat is mounted at 20" (508 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0228	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Door is swing into ambulatory accessible compartment (stall) clear floor space.	§604.8.2.2	Reverse door swing or reconfigure ambulatory accessible compartment (stall) to provide a 60"(1524 mm) min. depth and a minimum width of 35" and 37" (890 mm - 940 mm) max. (2010 ADA Fig. 604.8.2).
ACS	0231	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Ambulatory accessible compartment stall does not have side wall grab bars.	§604.8.2.3	Install two 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange, mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1, 604.8.2).
ACS	0232	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Doorway opening has a clear width of 22.5" (572 mm) on each active leaf.	§404.2.3	Rework doors to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).
ACS	0233	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 61.25" (1556 mm) above the finished floor.	§308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0234	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Water closet is centered at 20" (508 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0236	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Transfer shower stall is 36" by 36.25" (914 by 921 mm) deep.	§608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1). <i>This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0237	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Transfer shower controls are mounted 61" (1549 mm) above the finished floor to the centerline	§608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.
ACS	0238	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Transfer shower grab bars are mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface	§608.3.1	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall; and mount between 33" and 36" (838 mm- 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.608.3.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0239	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	L-shaped seat is recessed 2" (51 mm) from the rear edge of the L-portion of the seat.	\$610.3.2	Provide an L-shaped seat that extends up to 3" (75 mm) max. from the shower compartment entry, that is recessed 2.5" (63 mm) max. from the seat wall and 1.5" (38 mm) max. from the rear edge of the L-portion of the seat (2010 ADA Fig. 610.3.2).
ACS	0240	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 55" (1397 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0241	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Shower spray hose control requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0249	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331	0050	1st	COM SPC	Outdoor Seating Area in Front of Main Entrance	Bench back support is mounted at 15" (381 mm) above the seat surface	\$903.4	We recommend providing a bench with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface to a point 18" (455 mm) min. above the seat surface (2010 ADA Fig. 903.4)
ACS	*0235	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Transfer shower controls and shower spray hose are not mounted within the control area (they are mounted on the back wall)	\$608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.
ACS	0012	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Lobby	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0029	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Men's Accessible Restroom by Cafeteria	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0229	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Ambulatory accessible compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.2.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0230	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	*0224	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Women's Restroom by Lobby	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0182	Senior Services	Harriet G. Darnell Senior Multipurpose	677 Fairburn Rd NW Atlanta, GA 30331		1st	COM SPC	Hair Stylist Room No. G201	This room was locked at time of survey, therefore it was not inspected	N/A	This room was locked at time of survey, therefore it was not inspected

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0003	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0003	1st	COM SPC	Women's Restroom	Maneuvering clearance on the pull side of the door is 12" (305 mm).	§404.2.4	Install an automatic door opener to comply with requirements for an 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor/leveled area with slopes not exceeding 1:48.
ACS	0010	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0005	1st	COM SPC	Stage Ramp 193	Permanent room identifying signage is mounted at 62" (1575 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0026	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0010	1st	COM SPC	Library Room 152	Permanent room identifying signage is mounted at 61.75" (1568 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0028	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0011	1st	COM SPC	Unisex Accessible Restroom in Front of Conference Room A	Partition encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Install an automatic door opener to comply with requirements for an 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor area (2010 ADA Fig. 404.2.4.1). Proposed correction is to post sign indicating the location of the accessible restrooms.
ACS	0031	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Computer Lab Room 158	Computer does not appear to have accessible software.	§508	True it or the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic and information technology. Per Section 508 ensure computer provides accessible hardware/software.
ACS	0033	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Activities Room B Room 159	Trash bin encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate trash bin to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).
ACS	0034	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0015	1st	COM SPC	Art Room 150	Garbage can encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate garbage can to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor area (2010 ADA Fig. 404.2.4.1).
ACS	0035	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0016	1st	COM SPC	Unisex Restroom in Front of Room 151	Partition encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Install an automatic door opener to comply with the requirements for an 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor area. (2010 ADA Fig. 404.2.4.1).
ACS	0043	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0020	1st	COM SPC	Women's Restroom/Showers/Lockers	Permanent room identifying signage is mounted at 64" (1626 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0053	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0025	1st	COM SPC	Fourth Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Chairs encroach on maneuvering clearance on the push side for a parallel hinge approach.	§404.2.4	Remove chairs and exercise equipment to provide the required 22" (560 mm) min. maneuvering clearance on the push side of the door, for a parallel hinge approach and 48" (1220 mm) min. deep clear floor area (2010 ADA Fig. 404.2.4.1).
ACS	0086	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0033	Grade	COM SPC	Seven Accessible Spaces on Right Side	Fourth accessible parking space from the right has 2.6 % non-compliant running slopes.	§502.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0087	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		Grade	COM SPC	Seven Accessible Spaces on Right Side	Fifth accessible parking space from the right has 2.6 % non-compliant running slopes.	§502.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0088	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		Grade	COM SPC	Seven Accessible Spaces on Right Side	Third access aisle from the right has up to a 3.3 % non-compliant running slope.	§502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.
ACS	0089	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0034	Grade	COM SPC	Accessible Route from Parking Lot to Main Entrance	Accessible route has a non-compliant cross slope of up to 3.5 %.	§403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0090	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0035	Grade	COM SPC	Accessible Route from Public Rights of Way	Accessible route has non-compliant cross slopes of 4.55 % that extends 25 ft (mt).	§403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0091	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		Grade	COM SPC	Accessible Route from Public Rights of Way	Accessible route has a non-compliant running slopes of 6.25 % that extends 25 ft (mt).	§403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%. Requires handrails.
ACS	0092	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		Grade	COM SPC	Accessible Route from Public Rights of Way	Accessible route after utility pole has a non-compliant running slope of 5.9 %.	§403.3	Rework or repave accessible route to provide a running slope not exceeding 2%. Or provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig 505.10.1)
ACS	0093	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		Grade	COM SPC	Accessible Route from Public Rights of Way	Accessible route after utility pole has a non-compliant cross slope of 3.3 %.	§403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0094	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		Grade	COM SPC	Accessible Route from Public Rights of Way	Curb ramp has a 11.8 % non-compliant running slope.	§406	Rework curb ramp to provide a running slope not to exceed 8.33%

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0095	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		Grade	COM SPC	Accessible Route from Public Rights of Way	The foot of the curb ramp is not flush.	\$406.2	The adjacent surfaces at transitions from curb ramps to walks, gutters, and streets shall be at the same level (2010 ADA Fig. 406.2).
ACS	0001	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0001	1st	COM SPC	Telephone in Main Lobby	Telephone is mounted at 56" (1422 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0002	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0002	1st	COM SPC	Water Fountains next to Restrooms by Main Lobby	Low drinking fountain spout outlet (orifice height) is mounted at 38" (965 mm) above the finished floor.	\$602.4	Install fountain at 36" (914 mm) max. above the finished floor to the spout outlet
ACS	0004	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 50" (1270 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0005	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom	Accessible toilet compartment is 48.5" (1232 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet. (2010 ADA Fig. 604.8.1.1).
ACS	0006	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 59.75" (1518 mm) above the finished floor to the highest operable part	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).
ACS	0007	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Men's Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 62.5" (1588 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object
ACS	0007	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0004	1st	COM SPC	Men's Restroom	Door swings into toilet compartment clear floor space and the stall is 52" (1320 mm) deep.	\$604.8.1.2	Rework partitions and/or fixtures to provide a 60" (1524 mm) min. wide by 56" (1422 mm) min. deep accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).
ACS	0009	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Men's Restroom	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0011	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Stage Ramp 193	Ramp does not have handrails on both sides.	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig. 505.10.1).
ACS	0012	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Stage Ramp 193	Ramp with a change in direction has a 58" (1473 mm) wide landing.	\$405.7.4	Rework ramp to provide 60" by 60" (1524 mm by 1524 mm) min. long landing, for ramps with a change of direction and runs rising over 30" (762 mm) (2010 ADA Fig. 405.7).
ACS	0013	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0006	1st	COM SPC	Telephone next to Dining Area	Telephone is mounted at 56" (1422 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0014	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0007	1st	COM SPC	Dining Area	Tray slide is mounted at 34.5" (876 mm) above the finished floor.	\$904.5.2	Provide a tray slide that is 28" (710 mm) min and 34" (865 mm) max above the finish floor.
ACS	0015	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0008	1st	COM SPC	Drinking fountains next to Shower Lockers	Drinking fountain is mounted in a 26.25" (667 mm) wide alcove.	\$305.7.1	Rework partitions to provide a 36" (914 mm) min. wide alcove for a forward approach to object (2010 ADA Fig. 305.7.1).
ACS	0016	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Drinking fountains next to Shower Lockers	Drinking fountain spout outlet (orifice height) is mounted at 38" (965 mm) above the finished floor.	\$602.4	Install drinking fountain at 36" (914 mm) max. above the finished floor to the spout outlet and provide a paper cup dispenser

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0017	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0009	1st	COM SPC	Men's Restroom/ Showers/ Lockers Room 141	Toilet seat cover dispenser is mounted beyond reach ranges at 55.5" (1410 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)</i>
ACS	0018	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Men's Restroom/ Showers/ Lockers Room 141	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 63.75" (1619 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).
ACS	0019	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Men's Restroom/ Showers/ Lockers Room 141	End shower stall does not have the required clear floor space for a transfer shower.	§608.2	Reconfigure end stall's fixtures and offset partitions to provide a 30" by 60" (762 mm by 1524 mm) min. shower stall with the required 30" by 60" (762 mm by 1525 mm) min. clear floor space. Remove end wall and add a side wall to convert this stall in to a roll in shower. (Fig. 608.2.2)
ACS	0020	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Men's Restrooms/ Showers/ Lockers	Shower controls are mounted at 49" (1245 mm) above the finished floor.	§608.5.2	Relocate and mount shower controls above the grab bar at 48" (1220 mm) max. above the finished floor to the highest operable part. If seat is provided, relocate and mount shower controls, faucets, and shower spray unit on the back wall adjacent to the seat wall and shall be located 27" (685 mm) maximum from the seat wall above the grab bar at 48" (1220 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 608.5.2).
ACS	0021	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Men's Restroom/ Shower/ Lockers	Shower controls require pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0022	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Men's Restroom/ Shower/ Lockers	Shower has non-compliant grab bar configuration.	§608.3	At roll-in shower, replace grab bar configuration, install grab bars on three walls, and mount between 33" and 36" (838 mm-914 mm) above the finished floor to the top of the gripping surface, 6" (150 mm) maximum from adjacent walls. If seat is provided, no grab bar is required over seat (ADAAG Fig. 608.3.2).
ACS	0023	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Men's Restroom/ Shower/ Lockers	Roll-in shower has a non-compliant curb.	§608.7	Rework roll-in shower curb so it does not exceed 0.5" (12 mm) in height.
ACS	0024	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Men's Restroom/ Showers/ Lockers Room 141	Bench is mounted at 23.5" (597 mm) above the finished floor.	§903.5	Rework bench to provide 17-19" (431mm-485 mm) above the finished floor seat height with armrests and supportive backrest design (for ease in sitting/standing) (2010 ADA Fig.903.4).
ACS	0025	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Men's Restroom/ Showers/ Lockers Room 141	Bench is 9" (229 by 229 mm) deep.	§903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.
ACS	0027	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Library Room 152	Books on highest shelf are mounted at a non-compliant height above the finished floor.	§308.2.1	Implement policy to assist library users by retrieving books from inaccessible shelves. Post signage displaying the International Symbol of Accessibility indicating that "Assistance is Available Upon Request" (§36.304 (f) and §36.305 (b) (3)).
ACS	0029	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0012	1st	COM SPC	Conference Room A	Ensure TV provides closed caption during business hours.	§36.303(e)	Replace existing TV set if needed with a closed caption compatible unit or install a caption decoder system.
ACS	0030	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0013	1st	COM SPC	Computer Lab Room 158	Fire extinguisher and printer encroach over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate fire extinguisher and printer to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).
ACS	0032	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0014	1st	COM SPC	Activities Room B Room 159	Ensure TV provides closed caption during business hours.	§36.303(e)	Replace existing TV set if needed with a closed caption compatible unit or install a caption decoder system.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0036	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Unisex Restroom in Front of Room 151	Toilet seat cover dispenser is mounted beyond reach ranges at 55" (1397 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0037	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Unisex Restroom in Front of Room 151	Furniture encroaches into the required diameter wheelchair turnaround space in room.	§304.3	Remove furniture to provide the required clear 60" (1524 mm) min. diameter wheelchair turnaround space or a T-shaped space. (2010 ADA Fig. 304.3.2).
ACS	0038	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Unisex Restroom in Front of Room 151	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 64" (1626 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).
ACS	0039	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0017	1st	COM SPC	Drinking Fountains Next to Land Fitness Room 144	Drinking fountain spout outlet (orifice height) is mounted at 47" (1194 mm) above the finished floor (For standing persons)	§602.7	Replace fountain with hi-lo unit and mount between 38" and 43" (965 mm - 1090 mm) above the finished floor to the spout outlet or install paper cup dispenser (For standing persons or people have difficulty bending or stooping).
ACS	0040	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0018	1st	COM SPC	Land Fitness Room 144	Exercise machines and equipment have a non-compliant clear floor space.	§1004.1	Relocate exercise machines and equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space, positioned for transfer or use by an individual seated in a wheelchair (2010 ADA Fig. 305.3, 305.5).
ACS	0041	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0019	1st	COM SPC	Therapeutic Pool Room 136	Shower controls are mounted at 51" (1295 mm) above the finished floor.	§608.5.2	Relocate and mount shower controls above the grab bar at 48" (1220 mm) max. above the finished floor to the highest operable part (For a standard roll-in shower with out a seat only) (2010 ADA Fig. 608.5.2).
ACS	0042	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Therapeutic Pool Room 136	Weights encroach over low drinking fountain clear floor space clear floor space.	§602.1	Relocate weights to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0044	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0021	1st	COM SPC	First Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Toilet seat cover dispenser is mounted beyond reach ranges at 55" (1397 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0045	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0022	1st	COM SPC	Second Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Toilet seat cover dispenser is mounted beyond reach ranges at 55" (1397 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0046	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Second Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Toilet tissue dispenser is mounted at 38" (965 mm) from rear wall to outer leading edge.	§604.9.6	Relocate toilet tissue dispenser to water closet side wall and mount at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0047	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Second Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Toilet tissue dispenser is mounted over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to water closet side wall and mount at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0048	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0023	1st	COM SPC	Third Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0049	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Third Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Toilet tissue is mounted over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to water closet side wall and mount at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0050	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Third Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Toilet tissue dispenser is mounted at 37" (940 mm) from rear wall to outer leading edge.	\$604.9.6	Relocate toilet tissue dispenser to water closet side wall and mount at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0051	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Third Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.
ACS	0052	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0024	1st	COM SPC	Clothes Rod In front of Fourth Unisex Restrooms at Adult Day Two Room 126	Clothes rod is mounted beyond required reach allowed for approach provided and is mounted at 63" (1600 mm) above the finished floor.	\$308.2.1	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0054	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Fourth Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Toilet seat cover dispenser is mounted beyond reach ranges at 56" (1422 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).
ACS	0055	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Fourth Unisex Restroom (From to Right to Left) at Adult Day One Room 126	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.
ACS	0056	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0026	1st	COM SPC	First Unisex Restroom (From Left to Right) at Adult Day Two Room 117	Toilet seat cover dispenser is mounted beyond reach ranges at 55" (1397 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).
ACS	0057	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0027	1st	COM SPC	Second Unisex Restroom (From Left to Right) at Adult Day Two Room 117	Toilet tissue dispenser is mounted over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to water closet side wall and mount at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0058	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Second Unisex Restroom (From Left to Right) at Adult Day Two Room 117	Toilet tissue dispenser is mounted at 37" (940 mm) from rear wall to outer leading edge.	\$604.9.6	Relocate toilet tissue dispenser to water closet side wall and mount at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0059	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Second Unisex Restroom (From Left to Right) at Adult Day Two Room 117	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.
ACS	0060	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0028	1st	COM SPC	Third Unisex Restroom (From Left to Right) at Adult Day Two Room 117	Toilet seat cover dispenser is mounted beyond reach ranges at 53" (1346 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).
ACS	0061	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Third Unisex Restroom (From Left to Right) at Adult Day Two Room 117	Toilet tissue dispenser is mounted at 38" (965 mm) from rear wall to outer leading edge.	\$604.9.6	Relocate toilet tissue dispenser to water closet side wall and mount at 7'-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0062	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0029	1st	COM SPC	Fourth Unisex Restroom (From Left to Right) at Adult Day Two Room 117	Wheelchairs encroach over maneuvering clearance on the push side of the door.	\$404.2.4	Relocate wheelchairs to provide the required 12" (304 mm) min. maneuvering clearance on the push side of the door handle side (2010 ADA Fig. 404.2.4.1).
ACS	0063	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Fourth Unisex Restroom (From Left to Right) at Adult Day Two Room 117	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.
ACS	0064	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Fourth Unisex Restroom (From Left to Right) at Adult Day Two Room 117	Toilet tissue dispenser is mounted over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to water closet side wall and mount at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar, there shall be a clearance of 1.5" (38 mm) below the side wall grab bar.</i>
ACS	0065	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Fourth Unisex Restroom (From Left to Right) at Adult Day Two Room 117	Toilet seat cover dispenser is mounted beyond reach ranges at 54.75" (1391 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).</i>
ACS	0067	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0030	1st	COM SPC	Clothes Rod In front of Fourth Unisex Restrooms at Adult Day Two Room 117	Clothes rod is mounted beyond required reach allowed for approach provided and is mounted at 62" (1575 mm) above the finished floor.	\$308.2.1	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0068	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0031	1st	COM SPC	Corridor in Front of Dining Room 106	Drinking fountain spout outlet (orifice height) is mounted at 38" (965 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet
ACS	0069	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312	0032	1st	COM SPC	Women's Restroom/Showers/Lockers	No accessible stall designated.	\$216.1	Provide sign indicating accessible stall.
ACS	0070	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Toilet seat cover dispenser is mounted beyond reach ranges at 55.25" (1403 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).</i>
ACS	0071	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 63.5" (1613 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).
ACS	0072	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Ambulatory accessible compartment (Stall) is 56.5" (1435 mm) by 33' wide.	\$604.8.2.1	As per 213.3.1, at least one ambulatory stall is required. Reconfigure ambulatory accessible (stall) to provide a 60"(1524 mm) min. depth and a minimum width of 35" and 37" (890 mm - 940 mm) max. (2010 ADA Fig. 604.8.2).
ACS	0073	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Door swings into toilet compartment clear floor space.	\$604.8.1.2	Rework partitions and/or fixtures to provide a 60" by 35" (1524 mm by 890 mm) min. accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).
ACS	0074	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Water closet is centered at 12.5" (318 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0075	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Water closet side wall grab bar is mounted at 48" (1219 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0076	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Toilet seat cover dispenser is mounted beyond reach ranges at 54" (1372 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).</i>
ACS	0077	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Lavatory is mounted at 34.5" (876 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.
ACS	0078	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0079	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	End shower stall is 41" by 65" (1041 by 1651 mm) and does not have the required clear floor space for a transfer shower.	\$608.2	Reconfigure last stall's fixtures and offset partitions to provide a 30" by 60" (762 mm by 1524 mm) min. shower stall with the required 30" by 60" (762 mm by 1525 mm) min. clear floor space. Remove end wall and add a side wall to convert this stall in to a roll in shower. (Fig. 608.2.2)
ACS	0080	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Shower controls are mounted at 49" (1245 mm) above the finished floor.	\$608.5.2	Relocate and mount shower controls above the grab bar at 48" (1220 mm) max. above the finished floor to the highest operable part. If seat is provided, relocate and mount shower controls, faucets, and shower spray unit on the back wall adjacent to the seat wall and shall be located 27" (685 mm) maximum from the seat wall above the grab bar at 48" (1220 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 608.5.2).
ACS	0081	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Shower controls require pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0082	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Shower has non-compliant grab bar configuration.	\$608.3	At roll-in shower, replace grab bar configuration, install grab bars on three walls, and mount between 33" and 36" (838 mm-914 mm) above the finished floor to the top of the gripping surface, 6" (150 mm) maximum from adjacent walls. If seat is provided, no grab bar is required over seat (ADAAG Fig. 608.3.2).
ACS	0083	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Roll-in shower stall must not have a curb at thresholds.	\$608.7	Rework roll-in shower curb so it does not exceed 0.5" (12 mm) in height.
ACS	0084	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Bench is mounted at 23" (584 mm) above the finished floor.	\$903.5	Rework bench to provide 17-19" (431mm-485 mm) above the finished floor seat height with armrests and supportive backrest design (for ease in sitting/standing) (2010 ADA Fig.903.4).
ACS	0085	Senior Services	Helene S. Mills Senior Multipurpose	515 John Wesley Dobbs Avenue NE Atlanta, GA 30312		1st	COM SPC	Women's Restroom/Showers/Lockers	Bench is 48" by 9.25" (1219 by 235 mm) wide.	\$903.3	Provide a bench that is 42" (1065 mm) min. long and 20"-24" (510 mm - 609 mm) max. deep.
ACS	0001	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0001	1st	COM SPC	Main Entrance	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.
ACS	0028	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0009	1st	COM SPC	TV Room	Furniture encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0030	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	TV Room	Cabinet encroaches over maneuvering clearance on the pull side of the door reducing it to 9" (229 mm)	\$404.2.4	Relocate cabinet to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0041	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0013	1st	COM SPC	Kevin Funk Computer Room	Computers do not appear to have accessible software	\$508	Title II of the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic and information technology.
ACS	0078	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0019	1st	COM SPC	Men's Locker Room by Pool Area	Maneuvering clearance on the pull side of the door is 50" (1270 mm) wide for a parallel latch approach.	\$404.2.4	Install an automatic door opener or rework partition to provide the required 24" (609 mm) min. maneuvering clearance on the pull side of the door for a parallel latch side approach and 54" (1370 mm) min. deep clear floor area (For door with a closer) (2010 ADA Fig. 404.2.4.1).
ACS	0097	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0021	1st	COM SPC	Dining Area	Dining room tables have a non-compliant knee clearance with a 11.5" (292 mm) horizontal projection.	\$902.2	Replace tables to provide 5% of the accessible seating spaces with the table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b))

Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0100	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0022	1st	COM SPC	Accessible Ramp From Dining Area Leading to Ramp Heading to Church St Entrance	Ramp does not have handrails on both sides.	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 A)
ACS	0101	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Ramp From Dining Area Leading to Ramp Heading to Church St Entrance	Ramp handrails do not have extensions.	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 A)
ACS	0103	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0024	1st	COM SPC	Church St Entrance From Public Rights-of-Way	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.
ACS	0104	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0025	1st	COM SPC	Door Leading to Transitional Lobby	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.
ACS	0105	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0026	1st	COM SPC	Ramp Leading to Transitional Lobby	Ramp with a slope of up to 5.8 % extends 10 ft (3.04 m) and does not have the required handrails.	\$405.8	Rework ramp to provide a slope not exceeding 5% or install handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Figs. 405.9.1, 405.9.2, 505.5.5, 505.5.6, 505.7.2, 505.10.1)
ACS	0106	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0027	1st	COM SPC	Ramp Leading to Back Stage Area	Ramp with a slope of up to 8.0 % does not have handrails on both sides.	\$405.8	Provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Figs. 405.9.1, 405.9.2, 505.5.5, 505.5.6, 505.7.2, 505.10.1)
ACS	0117	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0031	1st	COM SPC	Women's Locker Room by Pool Area	Maneuvering clearance on the pull side of the door is 46" (1168 mm) wide for a parallel latch approach.	\$404.2.4	Install an automatic door opener or rework door side partition to provide the required 24" (609 mm) min. maneuvering clearance on the pull side of the door for a parallel latch side approach and 54" (1370 mm) min. deep clear floor area (For door with a closer) (2010 ADA Fig. 404.2.4.1).
ACS	0137	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Passenger Loading Zone	Passenger loading zone does not have signage displaying the international symbol of accessibility.	\$503	Provide signage displaying the International symbol of accessibility at passenger loading zone.
ACS	0138	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Passenger Loading Zone	The surface of the accessible route has openings of up to 1" (25 mm) at the transition from the concrete to asphalt.	\$302.3	Rework floor surface to provide a 0.5" (12 mm) max. wide opening perpendicular to the dominant direction of travel (2010 ADA Fig.302.3)
ACS	0139	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0034	1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Accessible route has a non-compliant cross slope of 6.3 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0140	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Benches does not provide the required clear floor space parallel to the short axis of the bench.	\$903.2	We recommend reworking area or relocating benches to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space positioned at the end of the bench seat parallel to the short axis of the bench. with surface slopes not exceeding 2%
ACS	0141	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Accessible route has a non-compliant cross slope of 5.3 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0142	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Accessible route has a non-compliant cross slope of 4.3 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0143	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Accessible route has a non-compliant cross slope of 5.6 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0144	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Accessible route has a non-compliant cross slope of 3.3 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0145	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Accessible route has a non-compliant cross slope of 4.6 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0146	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0035	1st	COM SPC	Accessible Route From Main Entrance Leading to Dorsey Avenue	Accessible route has a 1" (25 mm) vertical change in level.	\$403.4	Rework accessible route to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 or mitigate condition by means of a curb ramp or ramp (2010 ADA Fig. 303.3).
ACS	0147	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route From Main Entrance Leading to Dorsey Avenue	Accessible route has a non-compliant running slope of 6.5 % that extends 30 ft (9.44 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 5%.
ACS	0148	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route From Main Entrance Leading to Dorsey Avenue	Accessible route has a non-compliant running slope of 6.1 % that extends 20 ft (6.08 mt).	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.
ACS	0149	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0036	1st	COM SPC	Public Rights-of-Way Entrance (Dorsey Avenue)	There is no signage posted indicating the location of an accessible entrance.	\$216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0150	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Public Rights-of-Way Entrance (Dorsey Avenue)	Curb ramp has a 10.2 % non-compliant running slope.	\$406	Rework curb ramp to provide a running slope not to exceed 8.33%.
ACS	0151	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0037	1st	COM SPC	Six Accessible parking Spaces by Entrance to Adult Day Care Center	Accessible parking spaces are not clearly outlined or need re-stripping.	\$502.3.1	Restripe to provide an accessible parking space 96" (2438 mm) min. wide and a 60" (15258 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.3).
ACS	0152	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Six Accessible parking Spaces by Entrance to Adult Day Care Center	First accessible parking space (from left to right) has a non-compliant surface slope of up to 5.2%.	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0155	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Six Accessible parking Spaces by Entrance to Adult Day Care Center	Third accessible parking space (from left to right) has a non-compliant surface slope of up to 2.9%.	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	0156	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Six Accessible parking Spaces by Entrance to Adult Day Care Center	Second access aisle (from left to right) has a 2.9 % non-compliant surface slope.	\$502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.
ACS	0161	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route From Accessible Parking Spaces Leading to Adult Day Care Center	Accessible route has a non-compliant cross slope of 3.4 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0162	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route From Accessible Parking Spaces Leading to Adult Day Care Center	Accessible route has a non-compliant cross slope of 2.7 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0163	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route From Accessible Parking Spaces Leading to Adult Day Care Center	Accessible route has a non-compliant running slope of 9.4 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.
ACS	0164	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route From Accessible Parking Spaces Leading to Adult Day Care Center	Accessible route has a non-compliant cross slope of 3.1 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0165	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0038	1st	COM SPC	Ramp Leading to Multipurpose Center and Adult Day Care Center	Ramp with a change in direction has a 53.5" by 56" (1359 by 1422 mm) wide landing.	\$405.7.4	Relocate ramp handrails outside of the intermediate landing to provide 60" by 60" (1524 mm by 1524 mm) min. long landing, for ramps with a change of direction and runs rising over 30" (762 mm) (2010 ADA Fig. 405.7).
ACS	0166	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Ramp Leading to Multipurpose Center and Adult Day Care Center	There is no signage posted indicating the location of an accessible entrance.	\$216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).
ACS	0168	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Ramp Leading to Multipurpose Center and Adult Day Care Center	Maneuvering clearance on the pull side of the gate is 10" (254 mm).	\$404.2.4	Reverse door swing to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).
ACS	0169	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0039	1st	COM SPC	Accessible Route From Accessible Parking Spaces Leading to Adult Day Care Center	There is no signage posted indicating the location of an accessible entrance.	\$216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).
ACS	0170	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route From Accessible Parking Spaces Leading to Adult Day Care Center	Accessible route has a non-compliant cross slope of 5.0 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0171	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route From Accessible Parking Spaces Leading to Adult Day Care Center	Accessible route has a non-compliant cross slope of 5.5 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0172	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route From Accessible Parking Spaces Leading to Adult Day Care Center	Accessible route has a non-compliant cross slope of 4.8 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0173	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0040	1st	COM SPC	Passenger Loading Zone	Passenger loading zone does not have signage displaying the international symbol of accessibility.	\$503	Provide signage displaying the International symbol of accessibility at passenger loading zone.
ACS	0174	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Passenger Loading Zone	Passenger loading zone access aisle needs to be striped.	\$503.3.1	Restripe area to provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).
ACS	0175	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0041	1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Accessible route has a non-compliant cross slope of 2.5 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0176	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Accessible route has a non-compliant cross slope of 2.5 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0177	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Accessible route has a non-compliant cross slope of 2.5 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0178	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Accessible Route Adjacent to Passenger Loading Zone	Accessible route has a non-compliant cross slope of 2.3 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.
ACS	0179	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0042	1st	COM SPC	Main Entrance to Adult Daycare Center	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.
ACS	0181	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0044	1st	COM SPC	Dining Room No. 102	Room description characters on sign are not raised.	\$703.4.1	We recommend providing signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0182	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0045	1st	COM SPC	Personal Care Office No. 102	Room description characters on sign are not raised.	\$703.4.1	We recommend providing signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0185	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0047	1st	COM SPC	Beauty Shop Room No. 105	Room description characters on sign are not raised.	\$703.4.1	We recommend providing signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0186	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Beauty Shop Room No. 105	Vision lights are mounted at 55.5" (1410 mm) above the finished floor.	\$404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.
ACS	0191	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0051	1st	COM SPC	Resting Room No. 0113	Room description characters on sign are not raised.	\$703.4.1	We recommend providing signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0194	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0053	1st	COM SPC	Therapy Room No. 0114	Room description characters on sign are not raised.	\$703.4.1	We recommend providing signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0200	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0054	1st	COM SPC	Personal Care Room No. 0115	Room description characters on sign are not raised.	\$703.4.1	We recommend providing signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0201	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0055	1st	COM SPC	Unisex Accessible Restroom No. 0122 in Day Room 1	Maneuvering clearance on the pull side of the door is 3.75" (95 mm) due to a column and it is recessed 9" (229 mm).	\$404.2.4	Install an automatic door opener or invert the location of hinges on door so that it provides the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	0220	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0120 in Day Room 1	Door has a non-compliant opening force of 7 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.
ACS	0238	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0059	1st	COM SPC	Nurses' Office No. 0123	Room description characters on sign are not raised.	\$703.4.1	We recommend providing signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0267	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0129 in Day Room 2	Maneuvering clearance on the pull side of the door is 4.75" (121 mm) and it is recessed 9" (229 mm).	\$404.2.4	Install an automatic door opener or invert the location of hinges on door so that it provides the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).
ACS	*0102	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0023	1st	COM SPC	Accessible Ramp From Dining Area Leading to Church St Entrance	Ramp handrails do not have extensions.	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA 505.10.1)
ACS	*0135	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0032	1st	COM SPC	Curb Ramp Leading to Passenger Loading Zone	Curb ramp has up to a 10.9 % non-compliant running slope.	\$406	Rework curb ramp to provide a running slope not to exceed 8.33%
ACS	*0136	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0033	1st	COM SPC	Passenger Loading Zone	Passenger loading zone has non-compliant surface slope of up to 4.6%	\$503.4	Restripe to provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).
ACS	*0153	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Six Accessible parking Spaces by Entrance to Adult Day Care Center	First access aisle (from left to right) has a 2.4 % non-compliant surface slope.	\$502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.
ACS	*0154	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Six Accessible parking Spaces by Entrance to Adult Day Care Center	Second accessible parking space (from left to right) has a non-compliant surface slope of up to 3.0%	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0157	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Six Accessible parking Spaces by Entrance to Adult Day Care Center	Fourth accessible parking space (from left to right) has a non-compliant surface slope of up to 3.5%	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0158	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Six Accessible parking Spaces by Entrance to Adult Day Care Center	Fifth accessible parking space (from left to right) has a non-compliant surface slope of up to 3.7%	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.
ACS	*0159	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Six Accessible parking Spaces by Entrance to Adult Day Care Center	Third access aisle (from left to right) has a 3.6 % non-compliant surface slope.	\$502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.
ACS	*0160	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Six Accessible parking Spaces by Entrance to Adult Day Care Center	Sixth accessible parking space (from left to right) has a non-compliant surface slope of up to 3.5%	\$502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.
ACS	*0167	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Ramp Leading to Multipurpose Center and Adult Day Care Center	The top portion (of the second leg of ramp has a non-compliant surface slope of up to 9.6 % extending 15 ft (4.57 m)	\$405.2	Rework ramp to provide a running slope not exceeding 8.33%.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0004	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0004	1st	COM SPC	Men's Accessible Restroom by Library Reading Room	Toilet seat cover dispenser is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)</i>
ACS	0006	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Library Reading Room	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.
ACS	0007	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Library Reading Room	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). <i>For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0008	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Library Reading Room	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for these elements.</i>
ACS	0009	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Library Reading Room	Shelf is mounted beyond required reach allowed for approach provided and is mounted at 39" (991 mm) above the finished floor.	\$603.4	Lower or install shelf between 40"- 48" (1016 mm -1219 mm) max. above the finished floor for forward approach to object. <i>Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>
ACS	0010	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0005	1st	COM SPC	Game Room	Table surface is mounted at 40.5" (1029 mm) above the finished floor to the top.	\$902.3	Rework/replace tables to provide the top of the dining or work surface, mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.
ACS	0011	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Game Room	Tables have a non-compliant knee clearance and non-compliant clear floor space due to pedestal base.	\$902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.
ACS	0012	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0006	1st	COM SPC	Activity Area B	Sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0013	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Activity Area B	Kitchen sink counter does not have the required knee clearance due to pipes and garbage disposal.	\$804.3.1	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3)
ACS	0014	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Activity Area B	Sink knee clearance is 26.5" (673 mm) above the finished floor to bottom leading edge of fixture.	\$804.3.1	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture of fixture at an 8" (203 mm) min. horizontal projection, knee clearance must be 30" (762 mm) min. wide (2010 ADA Fig. 306.3)
ACS	0015	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Activity Area B	Kitchen outlet is mounted beyond required reach allowed for approach provided at 45.5" (1156 mm) above the finished floor over an obstruction (counter).	\$308.2.1	Lower or install soap dispense at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction (2010 ADA Fig. 308.2.1).
ACS	0016	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0007	1st	COM SPC	Activity Area B	TV protrudes into walkway, projecting 5.5" (140 mm) from back wall, and is mounted at 56.5" (1435 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess TV so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).
ACS	0018	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Activity Area B	Secondary sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.
ACS	0019	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Activity Area B	Secondary sink knee clearance is 26.5" (673 mm) above the finished floor to bottom leading edge of fixture.	\$804.3.1	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture of fixture at an 8" (203 mm) min. horizontal projection, knee clearance must be 30" (762 mm) min. wide (2010 ADA Fig. 306.3)
ACS	0020	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Activity Area B	Paper towel dispenser is mounted beyond required reach allowed for approach provided at 45.5" (1156 mm) above the finished floor to the highest operable part over a 24.5" (622 mm) obstruction (counter).	\$308.2.1	Install paper towel dispenser at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction, and at 15" (381 mm) min. above the finished floor to the centerline for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0021	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0008	1st	COM SPC	Women's Accessible Restroom by Library Reading Room	Water closet side wall grab bar is mounted at 53.25" (1353 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0022	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Library Reading Room	Toilet tissue dispenser is mounted at 6.5" (165 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.
ACS	0023	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Library Reading Room	Lavatory is mounted at 47.25" (1219 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$604.3.1	Reconfigure restroom's fixtures and/or urser pan walls to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping
ACS	0024	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Library Reading Room	Shelf is mounted beyond required reach allowed for approach provided and is mounted at 39.5" (1003 mm) above the finished floor.	\$603.4	Lower or install shelf between 40"- 48" (1016 mm -1219 mm) max. above the finished floor for forward approach to object. Elements in compliance with the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0025	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Library Reading Room	Lavatory mirror is mounted at 40.25" (1022 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface. For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0026	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Library Reading Room	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.25" (1429 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0027	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Library Reading Room	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 65.75" (1670 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).
ACS	0031	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0010	1st	COM SPC	Activity Room No.1 in Arts and Crafts Section	Sink has unwrapped bottom pipes.	§804.4	Cover (insulate) sink bottom supply and drain pipes.
ACS	0032	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Activity Room No.1 in Arts and Crafts Section	Sink knee clearance is 26.5" (673 mm) above the finished floor to bottom leading edge of fixture.	§804.3.1	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3)
ACS	0033	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Activity Room No.1 in Arts and Crafts Section	Paper towel dispenser is mounted beyond required reach allowed for approach provided at 53.25" (1352 mm) above the finished floor over a 24.5" (622 mm) obstruction (counter).	§308.2.1	Install paper towel dispenser at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction, and at 15" (381 mm) min. above the finished floor to the centerline for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0034	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Activity Room No.1 in Arts and Crafts Section	Shelf is mounted at 54.25" (1378 mm) above the finished floor to highest shelf.	§308.2.1	Lower or install shelf at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction (2010 ADA Fig. 308.2.1).
ACS	0035	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0011	1st	COM SPC	Ceramics Room H in Arts and Crafts Section	Sink has unwrapped bottom pipes.	§804.4	Cover (insulate) sink bottom supply and drain pipes.
ACS	0036	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Ceramics Room H in Arts and Crafts Section	Sink knee clearance is 26.5" (673 mm) above the finished floor to bottom leading edge of fixture.	§804.3.1	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3)
ACS	0037	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Ceramics Room H in Arts and Crafts Section	Paper towel dispenser is mounted beyond required reach allowed for approach provided at 54.25" (1378 mm) above the finished floor over a 24.5" (622 mm) obstruction (counter).	§308.2.1	Install paper towel dispenser at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction, and at 15" (381 mm) min. above the finished floor to the centerline for forward approach to object (2010 ADA Fig. 308.2.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0038	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Ceramics Room H in Arts and Crafts Section	Shelf is mounted at 54.5" (1384 mm) above the finished floor to highest shelf.	\$308.2.1	Lower or install shelf at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction (2010 ADA Fig. 308.2.1).
ACS	0042	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Kevin Funk Computer Room	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 50.25" (1276 mm) above the finished floor.	\$308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0043	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0014	1st	COM SPC	Senior Health Care Center	Counter is mounted at 38.25" (972 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).
ACS	0044	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0015	1st	COM SPC	Restroom in Senior Health Care Center	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 62.5" (1588 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.
ACS	0045	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Restroom in Senior Health Care Center	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.
ACS	0046	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Restroom in Senior Health Care Center	Lavatory mirror is mounted at 41.75" (1060 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0047	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Restroom in Senior Health Care Center	Lavatory is mounted at 41.25" (1048 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0048	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Restroom in Senior Health Care Center	Toilet tissue dispenser is mounted at 1" (25 mm) below the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser and mount at 1.5" (38 mm) min. below the side wall grab bar (2010 ADA Fig. 609.3).
ACS	0049	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Restroom in Senior Health Care Center	Toilet tissue dispenser is mounted at 4.75" (121 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0050	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Lobby Waiting Area	Soap dispenser is mounted beyond required reach allowed for approach provided at 47.75" (1213 mm) above the finished floor over a 24.25" (616 mm) obstruction (counter).	§308.2.1	Install soap dispenser at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction, and at 15" (381 mm) min. above the finished floor to the centerline for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0053	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Lobby Waiting Area	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 64.25" (1632 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).
ACS	0054	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Lobby Waiting Area	Accessible toilet compartment (stall) is 58.75" (1492 mm) deep by 59.5" 1511 mm) wide.	§604.8.1.1	Relocate stall partitions and/or fixtures to provide a 60" (1524 mm) wide by 56" 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).
ACS	0055	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Lobby Waiting Area	Water closet side wall grab bar is mounted at 52.5" (1334 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1) Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0056	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Lobby Waiting Area	Toilet tissue dispenser is mounted at 4.25" (108 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.
ACS	0057	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Lobby Waiting Area	Water closet is centered at 19" (483 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0059	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 49.55" (1276 mm) above the finished floor to centerline of the highest operable part.	§308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor to the centerline of highest operable part (2010 ADA Fig. 308.2.1).
ACS	0060	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Door swings into thermostat clear floor space.	§305.3	Relocate thermostat to provide an unobstructed 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at thermostat (2010 ADA Figs. 305.3-305.5).
ACS	0061	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the centerline of the highest operable part for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0064	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Door swings into toilet compartment clear floor space.	§604.8.1.2	Reverse door swing and/or install double acting hinges to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).
ACS	0065	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 64.25" (1632 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0066	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Water closet seat is mounted at 19.25" (489 mm) above the finished floor to top.	§604.4	Install a new low profile water closet seat/lid combination and install between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0067	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Toilet tissue dispenser is mounted at 3.5" (89 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.
ACS	0068	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Toilet seat cover dispenser is mounted at 1" (25 mm) below the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser and mount at 1.5" (38 mm) min. below the side wall grab bar (2010 ADA Fig. 609.3).
ACS	0069	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Accessible toilet compartment (stall) is 58.5" (1486 mm) deep by 59" (1499 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" (1524 mm) min. wide by 56" (1422 mm) min. deep accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).
ACS	0070	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0017	1st	COM SPC	Pool Area	Furniture encroaches over telephone clear floor space.	§305.3	Relocate furniture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0072	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Pool Area	Pool lift is mounted at 24.25" (616 mm) above the deck surface to the top of the seat.	§1009.2.4	Provide a pool lift that allows a stop at 16" to 19" (405 mm - 485 mm) measured from the deck to the top of the seat surface when in the raised (load) position (2010 ADA Fig. 1009.2.4).
ACS	0073	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Pool Area	The pool lift is mounted in an area where the water level exceeds a depth of 48" (1220 mm).	§1009.2.1	Relocate the pool lift and mount in the area of the pool where the water level does not exceed 48" (1220 mm).
ACS	0074	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Pool Area	Pool lift mechanism does not appear capable of unassisted operation from the deck and water levels (no remote control on lift)	§1009.2.7	Provide a pool lift that is capable of unassisted operation from the deck and water levels.
ACS	0075	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Pool Area	Bench is mounted at 16.25" (413 mm) above the finished floor.	§903.5	We recommend as best practice providing a bench mounted 17"-19" (431mm-485 mm) above the finished floor seat height with armrests and supportive backrest design (for ease in sitting/standing) (2010 ADA Fig.903.4).
ACS	0076	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0018	1st	COM SPC	Pool Manager's Office	Doorway has a non-compliant vertical change of level at door threshold.	§404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (2010 ADA Fig. 303.3).
ACS	0079	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0020	1st	COM SPC	Men's Locker Room by Pool Area	Dressing room bench is 9.25" (235 mm) wide and it is not fixed to a wall.	§803.4	Provide a 20" to 24" (508 mm - 609 mm) max. deep bench, that is 42" (1065 mm) long minimum, fixed to a wall, and mounted 17" min. to 19" max. (431 mm-482 mm) above the finished floor to top of bench.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0080	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Locker hardware requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0081	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.
ACS	0082	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Soap dispenser is mounted beyond required reach allowed for approach provided at 48" (1219 mm) above the finished floor over an obstruction (counter).	\$308.2.1	Install soap dispenser at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction, for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0083	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Urinal is mounted at 18.5" (470 mm) above the finished floor to top of rim.	\$605.2	Lower urinal and mount at 17" (431 mm) max. above the finished floor to top of rim. (2010 ADA Fig. 605.2)
ACS	0086	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Toilet seat cover dispenser is mounted on top of the rear wall grab bar.	\$609.3	Relocate toilet seat cover dispenser and mount between 13" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 42" (1067 mm) above the seat.</i>
ACS	0087	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0088	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 50" (1270 mm) above the finished floor to the centerline of the highest operable part.	\$308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor to the centerline of the highest operable part (2010 ADA Fig. 308.2.1).
ACS	0089	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Transfer shower has non-compliant grab bar configuration that extends over the transfer shower seat.	\$608.3.1	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall; and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.608.3.1).
ACS	0090	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Transfer shower seat does not extend from the back wall to a point of 3" (76 mm) max. of the compartment entry.	\$608.4	Provide an L-shaped seat with the front edge mounted at 15"- 16" (380 mm - 405 mm) max. from the wall, the end of the "L" shape shall be 22"-23" (560 mm - 585 mm) max. long and the front edge of the "L" portion 14"-15" (355 mm - 380 mm) max. from the wall.
ACS	0091	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Transfer shower seat has non-compliant dimensions.	\$608.4	Provide an L-shaped seat with the front edge mounted at 15"- 16" (380 mm - 405 mm) max. from the wall, the end of the "L" shape shall be 22"-23" (560 mm - 585 mm) max. long and the front edge of the "L" portion 14"-15" (355 mm - 380 mm) max. from the wall.
ACS	0092	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Transfer shower stall is 42" (1067 mm) deep by 36.5" (927 mm) wide.	\$608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0093	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Transfer shower control requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0094	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Soap dispenser is mounted at a non-compliant height over the side wall grab bar.	\$609.3	Relocate soap dispenser and mount at 48" (1219 mm) max. above the finished floor to the dispenser outlet. If mounted below the grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0096	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Accessible route leading to shower has a non-compliant running slope of 5.6 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.
ACS	0098	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Dining Area	Beverage dispenser is mounted at 50" (1270 mm) above the finished floor to highest operable part.	\$308.2.1	Lower or install beverage dispenser at 48" (1219 mm) max. above the finished floor to highest operable part (2010 ADA Fig. 308.2.1).
ACS	0099	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Dining Area	Coffee dispenser is mounted at 56" (1422 mm) above the finished floor to highest operable part.	\$308.2.1	Lower or install coffee dispenser at 48" (1219 mm) max. above the finished floor to highest operable part (2010 ADA Fig. 308.2.1).
ACS	0107	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0028	1st	COM SPC	Drinking Fountains by Cafeteria	Low drinking fountain spout outlet (orifice height) is mounted at 39.5" (1003 mm) above the finished floor.	\$602.4	Replace fountain with hi-lo unit or install additional unit and mount at 36" (914 mm) max. above the finished floor to the spout outlet.
ACS	0108	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Drinking Fountains by Cafeteria	High drinking fountain spout outlet (orifice height) is mounted at 44" (1118 mm) above the finished floor (For standing persons)	\$602.7	Replace fountain with hi-lo unit and mount between 38" and 43" (965 mm - 1090 mm) above the finished floor to the spout outlet or install paper cup dispenser (For standing persons or people have difficulty bending or stooping).
ACS	0109	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0029	1st	COM SPC	Unisex Accessible Restroom by Dining Area	Toilet tissue dispenser is mounted 0.25" (6 mm) below the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser and mount at 1.5" (38 mm) min. below the side wall grab bar (2010 ADA Fig. 609.3).
ACS	0110	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom by Dining Area	Water closet side wall grab bar is mounted at 52.5" (1334 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0111	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom by Dining Area	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0112	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom by Dining Area	Water closet seat is mounted at 19.5" (495 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0113	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom by Dining Area	Lavatory mirror is mounted at 40.5" (1029 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.
ACS	0114	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom by Dining Area	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 55.75" (1416 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).
ACS	0115	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0030	1st	COM SPC	Fitness Room	Exercise machines and equipment have a non-compliant clear floor space.	\$1004.1	Relocate exercise machines and equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space, positioned for transfer or use by an individual seated in a wheelchair (2010 ADA Fig. 305.3, 305.5).
ACS	0118	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Dressing room bench is 9.25" (235 mm) deep and it is not fixed to a wall.	\$803.4	Provide a 20" to 24" (508 mm - 609 mm) max. deep bench, that is 42" (1065 mm) long minimum, fixed to a wall, and mounted 17" min. to 19" max. (431 mm-482 mm) above the finished floor to top of bench.
ACS	0119	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Locker hardware requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0120	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Hand dryer protrudes into walkway, projecting 5" (127 mm) from back wall, and is mounted at 37" (940 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess hand dryer so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).
ACS	0121	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.
ACS	0122	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Soap dispenser is mounted beyond required reach allowed for approach provided at 49" (1245 mm) above the finished floor over a an obstruction (counter).	\$308.2.1	Install soap dispenser at 44" (1219 mm) max. above the finished floor, over a 20"- 25" (510 mm - 1120 mm) max. obstruction, and at 15" (381 mm) min. above the finished floor to the centerline for forward approach to object (2010 ADA Fig. 308.2.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0125	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Water closet rear wall grab bar is mounted at 36.25" (921 mm) above the finished floor to the top of the gripping surface.	\$604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface. For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0126	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Water closet side wall grab bar is mounted at 36.25" (921 mm) above the finished floor to the top of the gripping surface.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1). For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0128	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Accessible route leading to showers has a non-compliant running slope of 6.3 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.
ACS	0129	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Transfer shower does not have a transfer seat.	\$608.4	Provide an L-shaped seat with the front edge mounted at 15" - 16" (380 mm - 405 mm) max. from the wall, the end of the "L" shape shall be 22"-23" (560 mm - 585 mm) max. long and the front edge of the "L" portion 14"-15" (355 mm - 380 mm) max. from the wall.
ACS	0130	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Soap dispenser is mounted at a non-compliant height over the side wall grab bar.	\$609.3	Relocate soap dispenser and mount 15" - 48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0131	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Transfer shower has non-compliant grab bar configuration that extends more than 18" (457 mm) from the control wall.	\$608.3.1	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall; and mount between 33" and 36" (838 mm- 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.608.3.1).
ACS	0132	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Shower spray hose control requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0133	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Transfer shower controls are not mounted on the control area.	\$608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.
ACS	0134	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Transfer shower stall is 41" (1041 mm) deep by 36.5" (927 mm) wide and does not have the required clear floor space.	\$608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1).
ACS	0180	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0043	1st	COM SPC	Brochure Rack by Reception Area	Brochure rack is mounted at 63.25" (1607 mm) above the finished floor to highest shelf.	\$308.2.1	Lower or install brochure rack at 48" (1219 mm) max. above the finished floor to highest shelf (2010 ADA Fig. 308.2.1).
ACS	0184	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0046	1st	COM SPC	Drinking Fountain by Beauty Shop	The low drinking fountain has a 25.75" (654 mm) knee clearance and the high drinking fountain (For standing persons) has spout outlet mounted at 37.5" (952 mm) above the finished floor.	\$602.1	Install low drinking fountain so that it provide a 27" (685 mm) min. knee clearance above the finished floor, that is 30" (762 mm) min. wide and 25" (635 mm) max. deep. Relocate high drinking fountain so that it is mounted between 38" and 43" (965 mm - 1090 mm) above the finished floor to the spout outlet (For

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0187	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Beauty Shop Room No. 105	Telephone is mounted at 52" (1321 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install telephone at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0188	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0048	1st	COM SPC	Lockers in Corridor	Locker hardware requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.
ACS	0189	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0049	1st	COM SPC	Elevator Lobby	Elevator hoist way entrance does not have raised and Braille floor designations on both jambs.	§407.2.3.1	Install raised floor designations on both jambs of elevator hoist way entrance and mount between 48"- 60" (1219 mm -1524 mm) above the finished floor to baseline of highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0190	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0050	2nd	COM SPC	Elevator Lobby	Elevator hoist way entrance does not have raised and Braille floor designations on both jambs.	§407.2.3.1	Install raised floor designations on both jambs of elevator hoist way entrance and mount between 48"- 60" (1219 mm -1524 mm) above the finished floor to baseline of highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0193	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Resting Room No. 0113	Sleeping area does not provide the required clear floor space on both sides of the bed.	§806.2.3	Reconfigure room's furniture to provide a 30" by 48" (762 mm by 1219 mm) min. clear floor space on each side of the bed, positioned for a parallel approach to the side of the bed, or provide a single clear floor space between the beds (2010 ADA Fig. 305.5).
ACS	0195	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Therapy Room No. 0114	Exercise machines and equipment have a non-compliant clear floor space.	§1004.1	Relocate exercise machines and equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space, positioned for transfer or use by an individual seated in a wheelchair (2010 ADA Fig. 305.3, 305.5).
ACS	0199	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Therapy Room No. 0114	First aid kit is mounted at a non-compliant height above the finished floor.	§308.2.1	Lower or install first aid kit at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).
ACS	0202	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0122 in Day Room 1	Tissue dispenser is mounted behind the water closet.	§308.2.1	Relocate tissue dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0203	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0122 in Day Room 1	Water closet side wall grab bar is mounted at 46" (1168 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)

Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0205	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0122 in Day Room 1	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0206	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0122 in Day Room 1	Tissue dispenser is mounted behind the water closet.	§308.2.1	Relocate tissue dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)</i>
ACS	0207	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0122 in Day Room 1	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). <i>For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0208	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0122 in Day Room 1	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.
ACS	0209	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0122 in Day Room 1	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter. <i>For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0212	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0121 in Day Room 1	Water closet side wall grab bar is mounted at 46" (1168 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0213	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0121 in Day Room 1	Water closet side wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0214	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0121 in Day Room 1	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).
ACS	0215	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0121 in Day Room 1	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.
ACS	0216	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0121 in Day Room 1	Tissue dispenser is mounted 5.25" (133 mm) over the rear wall grab bar.	§609.3	Relocate tissue dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab</i>

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0218	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0121 in Day Room 1	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0221	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0120 in Day Room 1	Water closet side wall grab bar is mounted at 46" (1168 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0222	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0120 in Day Room 1	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0224	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0120 in Day Room 1	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).
ACS	0225	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0120 in Day Room 1	Water closet rear wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	\$604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.
ACS	0226	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0120 in Day Room 1	Tissue dispenser is mounted 5.5" (138 mm) over the rear wall grab bar.	\$609.3	Relocate tissue dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)
ACS	0227	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0120 in Day Room 1	Water closet is centered at 18.5" (470 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0228	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0120 in Day Room 1	Lavatory is mounted at 37" (940 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0230	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0119 in Day Room 1	Water closet side wall grab bar is mounted at 46" (1168 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0231	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0119 in Day Room 1	Water closet side wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0233	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0119 in Day Room 1	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).
ACS	0234	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0119 in Day Room 1	Water closet rear wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	\$604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.
ACS	0235	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0119 in Day Room 1	Tissue dispenser is mounted 5.75" (146 mm) over the side wall grab bar.	\$609.3	Relocate tissue dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar . If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)</i>
ACS	0236	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0119 in Day Room 1	Lavatory is mounted at 35" (889 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.
ACS	0239	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Nurses' Office No. 0123	Mat is not securely attached to the floor.	\$302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).
ACS	0242	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0060	1st	COM SPC	Day Room 2 No. 0125	Hand sanitizer dispenser is mounted at 49.5" (1257 mm) above the finished floor to highest operable part.	\$308.2.1	Lower or install hand sanitizer dispenser at 48" (1219 mm) max. above the finished floor to highest operable part (2010 ADA Fig. 308.2.1). <i>For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>
ACS	0249	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0126 in Day Room 2	Water closet side wall grab bar is mounted at 46" (1168 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0250	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0126 in Day Room 2	Water closet side wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0252	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0126 in Day Room 2	Water closet has a 30" (762 mm) long rear wall grab bar.	\$604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0253	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0126 in Day Room 2	Water closet rear wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.
ACS	0254	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0126 in Day Room 2	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).
ACS	0255	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0126 in Day Room 2	Water closet seat is mounted at 19.5" (495 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.
ACS	0258	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0128 in Day Room 2	Water closet side wall grab bar is mounted at 46" (1168 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0259	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0128 in Day Room 2	Water closet side wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0261	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0128 in Day Room 2	Toilet seat cover dispenser is mounted beyond reach ranges at 51" (1295 mm) above the finished floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical
ACS	0262	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0128 in Day Room 2	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).
ACS	0263	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0128 in Day Room 2	Water closet rear wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.
ACS	0265	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0128 in Day Room 2	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	§606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter. For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0268	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0129 in Day Room 2	Water closet side wall grab bar is mounted at 46" (1168 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0269	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0129 in Day Room 2	Water closet side wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)

Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0271	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0129 in Day Room 2	Toilet seat cover dispenser is mounted beyond reach ranges at 50.25" (1276 mm) above the finished floor to the receptacle.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0272	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0129 in Day Room 2	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).
ACS	0273	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0129 in Day Room 2	Water closet rear wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.
ACS	0274	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0129 in Day Room 2	Tissue dispenser is mounted 5.75" (146 mm) over the rear wall grab bar.	§609.3	Relocate tissue dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig. 609.3).
ACS	0275	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0129 in Day Room 2	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0277	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0127 in Day Room 2	Water closet side wall grab bar is mounted at 46" (1168 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0278	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0127 in Day Room 2	Water closet side wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)
ACS	0280	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0127 in Day Room 2	Water closet has a 30" (762 mm) long rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig.604.5.2).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0281	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0127 in Day Room 2	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.
ACS	0282	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0127 in Day Room 2	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.
ACS	0283	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0065	1st	COM SPC	Outdoor Seating Area by Day Room 2	Tables have a non-compliant knee clearance due to the base.	§902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.
ACS	*0002	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0002	1st	COM SPC	Reception Desk	Lower portion of the desk has a non-compliant 26.5" (673 mm) knee clearance.	§902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection. An alternative writing surface (clipboard) has been provided.
ACS	*0003	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0003	1st	COM SPC	Forms Desk	Desk has a non-compliant 25.5" (648 mm) knee clearance.	§902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection. An alternative writing surface (clipboard) has been provided.
ACS	*0039	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Ceramics Room H in Arts and Crafts Section	Tables have a non-compliant 24.5" (622 mm) knee clearance and non-compliant clear floor space provided.	§902.2	Replace tables to provide 5% of the accessible seating spaces with the table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b))

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	*0058	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0016	1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Maneuvering clearance on the pull side of the door is 46" (1168 mm) wide for a parallel latch approach.	§404.2.4	Install an automatic door opener or rework area to provide the required 24" (609 mm) min. maneuvering clearance on the pull side of the door for a parallel latch side approach and 54" (1370 mm) min. deep clear floor area (For door with a closer) (2010 ADA Fig. 404.2.4.1).
ACS	*0071	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Pool Area	Desk has a non-compliant 26.5" (673 mm) knee clearance.	§902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.
ACS	0005	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Library Reading Room	Toilet seat cover dispenser is mounted 9.5" (241 mm) over the rear wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0017	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Activity Area B	TV provided does not have the closed caption feature turned on.	§36.303 (e)	Implement a policy to have the closed caption feature on during business hours.
ACS	0029	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	TV Room	TV provided does not have the closed caption feature turned on.	§36.303 (e)	Implement a policy to have the closed caption feature on during business hours.
ACS	0040	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0012	1st	COM SPC	Kevin Funk Computer Room	Permanent room identifying signage does not have Braille or raised characters and is mounted on the hinge side of door.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).
ACS	0051	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Lobby Waiting Area	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0052	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Accessible Restroom by Lobby Waiting Area	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0062	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0063	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Accessible Restroom by Lobby Waiting Area	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0077	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Pool Manager's Office	Furniture encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area(2010 ADA Fig. 404.2.4.1).
ACS	0084	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0085	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0095	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Men's Locker Room by Pool Area	Mats are not securely attached to the floor and the height exceeds 0.5" (12 mm) and is not beveled.	§302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).
ACS	0116	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Fitness Room	Exercise equipment encroaches passage width at some points reducing it to 36" (914 mm).	§403.5.1	Relocate exercise equipment to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).
ACS	0123	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.
ACS	0124	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.
ACS	0127	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Women's Locker Room by Pool Area	Chairs encroach into the accessible route leading to the showers reducing it to less than 36" (914 mm).	§403.5.1	Relocate chairs to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0183	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Personal Care Office No. 102	Furniture encroaches over maneuvering clearance on the push side of the door.	§404.2.4	Relocate furniture to provide the required 22" (560 mm) min. maneuvering clearance on the push side of the door, for a parallel hinge approach and 42" (1065 mm) min. deep clear floor area (2010 ADA Fig. 404.2.4.1)
ACS	0192	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0052	1st	COM SPC	Resting Room No. 0113	Furniture encroaches passage width reducing it to less than 36" (914 mm).	§403.5.1	Relocate furniture to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).
ACS	0196	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Therapy Room No. 0114	Chair encroaches over hand sanitizer clear floor space.	§305.3	Relocate chair to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at hand sanitizer (2010 ADA Figs. 305.3-305.5).
ACS	0197	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Therapy Room No. 0114	Chair encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate chair to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).
ACS	0198	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Therapy Room No. 0114	Furniture encroaches over thermostat and first aid kit clear floor space.	§305.3	Relocate furniture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at thermostat and first aid kit (2010 ADA Figs. 305.3-305.5).
ACS	0204	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0122 in Day Room 1	Toilet seat cover dispenser is mounted 7" (178 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0210	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0056	1st	COM SPC	Unisex Accessible Restroom No. 0121 in Day Room 1	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0211	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0121 in Day Room 1	Furniture encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate furniture 24" (609 mm) min. maneuvering clearance on the pull side of the door for a parallel latch side approach and 54" (1370 mm) min. deep clear floor area (For door with a closer) (2010 ADA Fig. 404.2.4.1).
ACS	0217	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0121 in Day Room 1	Toilet seat cover dispenser is mounted 7" (178 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0219	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0057	1st	COM SPC	Unisex Accessible Restroom No. 0120 in Day Room 1	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0223	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0120 in Day Room 1	Toilet seat cover dispenser is mounted 7" (178 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0229	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0058	1st	COM SPC	Unisex Accessible Restroom No. 0119 in Day Room 1	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0232	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0119 in Day Room 1	Toilet seat cover dispenser is mounted 7.5" (190 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0237	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0119 in Day Room 1	Toilet seat cover dispenser is mounted beyond reach ranges at 50.75" (1299 mm) above the finished floor to the receptacle.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0240	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Nurses' Office No. 0123	Boxes encroaches over hand sanitizer clear floor space.	§305.3	Relocate boxes to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at hand sanitizer (2010 ADA Figs. 305.3-305.5).
ACS	0241	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Nurses' Office No. 0123	Boxes encroach over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate boxes to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).
ACS	0243	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Day Room 2 No. 0125	TV provided does not have the closed caption feature turned on.	§36.303 (e)	Implement a policy to have the closed caption feature on during business hours.
ACS	0244	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Day Room 2 No. 0125	Furniture encroaches over thermostat clear floor space.	§305.3	Relocate furniture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).
ACS	0245	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Day Room 2 No. 0125	Furniture encroaches over hand sanitizer dispenser clear floor space.	§305.3	Relocate furniture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at hand sanitizer dispenser (2010 ADA Figs. 305.3-305.5).
ACS	0246	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Day Room 2 No. 0125	Furniture encroaches over telephone clear floor space.	§305.3	Relocate furniture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at telephone (2010 ADA Figs. 305.3-305.5).
ACS	0247	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Day Room 2 No. 0125	Equipment and wheelchairs encroach over clothes rod and hand sanitizer clear floor space.	§305.3	Relocate wheelchairs and equipment to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at clothes rod and hand sanitizer (2010 ADA Figs. 305.3-305.5).
ACS	0248	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0061	1st	COM SPC	Unisex Accessible Restroom No. 0126 in Day Room 2	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and
ACS	0251	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0126 in Day Room 2	Toilet seat cover dispenser is mounted 6.75" (171 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified

**Fulton County ADA Transition Plan
SENIOR SERVICES
Appendix 7-14**

RSC	Item No.	Department	Bldg Name	Address	Line	Fl.	Area Type: COM SPC/ PRGM	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction
ACS	0256	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0126 in Day Room 2	Toilet seat cover dispenser is mounted beyond reach ranges at 50" (1270 mm) above the finished floor to the receptacle.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the dispenser receptacle for unobstructed forward approach to object (2010 ADA Fig. 604.7). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0257	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0062	1st	COM SPC	Unisex Accessible Restroom No. 0128 in Day Room 2	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0260	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0128 in Day Room 2	Toilet seat cover dispenser is mounted 7.75" (197 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0264	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0128 in Day Room 2	Toilet seat cover dispenser is mounted 5" (127 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0266	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0063	1st	COM SPC	Unisex Accessible Restroom No. 0129 in Day Room 2	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0270	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0129 in Day Room 2	Toilet seat cover dispenser is mounted 7" (178 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0276	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344	0064	1st	COM SPC	Unisex Accessible Restroom No. 0127 in Day Room 2	Permanent room identifying signage is mounted at 62.5" (1588 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.
ACS	0279	Senior Services	HJC Bowden Senior Center	2885 Church Street East Point, GA 30344		1st	COM SPC	Unisex Accessible Restroom No. 0127 in Day Room 2	Toilet seat cover dispenser is mounted 7.5" (190 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.